## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI **HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2025/56

Dated: 23 01 2025

To,

The Principal, M. C. P. S. Girls Prahladpur Bangar, Delhi-110042.

Sub: Issue of FSC in r/o M. C. P. S. Girls Prahladpur Bangar, Delhi-110042.

Sir.

Kindly reference to online mail dated 12.12.2024, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 07.01.2025, in presence of Mrs. Joytii Bhardwaj to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

- 1. Accessible gate width is less than required width of 4.5m.
- 2. The width of alternate Staircase is 1.18 mtr against the required width of 1.50 mtr.
- 3. Alternate staircase is not continuous to terrace level.
- 4. Hose reel provided but not functional.
- 5. Terrace Fire pump with capacity of 450 LPM provided but not functional.
- Exit signage not provided.
- 7. Copy of approved drawings of school building may kindly be provided as the said block is a newly constructed building.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under subrule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:

http://www.delhi.gov.in/wps/wcm/connect/doit\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http:

//www.delhi.gov.in/wps/wcm/connect/doit\_fire/FIRE/Home/Forms

Yours faithfully