



e 29

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**

No F 6 / DFS / MS / EH / 2025 / SZ / 254

Dated 03/07/2025

**FIRE SAFETY CERTIFICATE**

Certified that **M/s Meira's Bakehouse** located at **D-2 Ground Floor & First floor, Defence Colony, Delhi-110024** is running at **Ground floor and first floor** in a building comprised of Ground floor plus two upper floors have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on **21.06.2025** in the presence of **Sh. Gaurav** and found that the building/ premises is fit for occupancy "**Assembly**" (**Group D**) **Restaurant at Ground floor and first floor** with effect from 03/07/2025 and valid up to 31/03/2028 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 03/07/2025 at New Delhi by

(Atul Garg)  
Director  
Delhi Fire Service  
GUR

Copy to:-

1. The Commissioner, MCD, Delhi:- to ensure the occupancy as detailed above and deviation if any.
2. The Owner/ Occupier M/s Meira's Bakehouse located at D-2 Ground Floor & First floor, Defence Colony, Delhi-110024.
3. MCD Portal ID No. 2025061009899.

**Conditions for the validity of Fire Safety Certificate:**

1. Fire Safety Certificate is valid for Ground and first floor only.
2. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
3. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate through MCD portal (<https://www.mcdonline.nic.in>) along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
9. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

**INSPECTION REPORT**

1. Name & address of the building : M/s Meira's Bakehouse located at D-2, Ground floor and First floor, Defence Colony, Delhi- 110024.
2. Type of Occupancy : Assembly (Restaurant at Ground and first floor Only)
3. Building Comprised of : Ground plus two upper floors.
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety directives letter No : Nil
7. Date of inspection : 21/06/2025
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers  
From the building side : Sh. Gaurav
10. Year of Construction : 2000 as per MCD Portal
11. Applicant's letter No. : MCD Application ID No. 2025061009899 dated 10/06/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ UBBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	Road width	9 m	Provided	MR
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	Upper Floors	02	Provided	MR
	Basements	NA	NA	NA
	b. Width of staircases			
	Upper Floor	1.5 m each	Provided	MR
	Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	02	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	2 x 1.5 m	Provided	MR
3.	<b>Compartmentation</b>			
	Fire check door	Required in kitchen	Provided	MR
	Sealing of electrical shafts	NA	NA	NA
	Fire Rating of shaft door	NA	NA	NA
	Water Curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4.	<b>Smoke Management System</b>			
	Basements	NA	NA	NA
	Upper Ground floor	Required	Natural Ventilation	MR
5.	<b>Fire Extinguishers</b>			
	Total numbers	06 Nos.	Provided	MR
	Types	ABC/Co2 Type	Provided	MR
	IS marking	Required	Provided	MR
6.	<b>First-Aid Hose Reels</b>			
	Total numbers on each floor	01	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7.	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	NA	NA	NA
	Location of Main Panel	NA	NA	NA
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters' Location	NA	NA	NA
8.	<b>MOEFA</b>			
		Required	Provided	MR

N-18

9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	Basement	NA	NA	NA
	Upper Floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	Size of riser/down-comer	100 mm	Provided	MR
	Number of hydrants per floor	01	Provided	MR
	Hose Box	01	Provided	MR
12.	Yard Hydrants			
	Total number of hydrants	NA	NA	NA
	Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	Ground Level			
	Discharge of main Pump	NA	NA	NA
	Head of Main pump	NA	NA	NA
	Number of main pumps	NA	NA	NA
	Jockey Pump out put	NA	NA	NA
	Jockey pump head	NA	NA	NA
	Standby Pump out put	NA	NA	NA
	Standby Pump Head	NA	NA	NA
	Auto Starting/Manual Stopping	NA	NA	NA
	Pump House Access	NA	NA	NA
	Terrace level			
	Discharge of pump	450 lpm	Provided	MR
	Head of the pump	40 m	Provided	MR
	Power Supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	20,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	NA	NA	NA
	Fireman's Grounding Switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	Total Area	NA	NA	NA
	Location	NA	NA	NA
19.	Fire Control Room			
	Detector System Panel	NA	NA	NA
	Flow Switch Panel	NA	NA	NA
	PA System Panel	NA	NA	NA
	Battery backup	NA	NA	NA
	Building Floor Plans	NA	NA	NA

N-19

Special Fire Protection System for  
Protection of special Risks, if any:

NA

NA

NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The management had rectified the shortcomings issued vide letter no. F-6/DFS/MS/EH/2025/SZ/185 dated 01/05/2025.

Keeping in view of satisfactory compliance of the minimum standards of fire prevention and fire safety measures as required under rules it is recommended to grant fire safety certificate under Rule 35 of the Delhi Fire Service Rules, 2010.

Signature of Inspecting Officer  
Name : Rajeev Kumar Sinha  
Designation : ADO/B.W.

Do (South) Pl. check according to the plans.

ADO (BW)

Srs. The premises has been inspected by the Undersign physically and the occupancy has been found according to plans submitted by the applicant on the MCD portal.

resubmitted for signature,

ADO (BW)  
24/6/25

Do (South)

ADO (BW)  
24/6/25

ADO  
30/6/25

Director

Dr. F-T letter is attached for signature,

ADO (BW)  
24/7/25