



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

C-64

NO. F-6/DFS/MS/EH/2025/ 149

Dated / 07/04/2025

To

The Joint Commissioner of Police/ Lic,  
1st Floor, Licensing Unit, Police Station  
Defence Colony, New Delhi.

Sub: - Regarding renewal of fire safety certificate in r/o M/s M.G Bakers Pvt. Ltd located at  
Ground floor & Mezzanine floor (storage), N-3, Connaught Place, New Delhi-110001.

Sir,

This has reference to online MCD Portal I.D no. 2025031803835 dated 18.03.2025 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 02.04.2025 in the presence of Sh. Gaurav (Manager) to check the existing fire safety measures. During inspection it has been observed that building is comprised of ground, mezz & 02 upper floors but restaurant is running at ground floor & mezzanine floor (storage) only. The request for FSC is rejected is rejected under Rule 37 (3) due to following shortcomings.

- 1 Hose reel hose is provided but not functional.
- 2 Smoke detector is provided but not functional.
- 3 MOEFA system is provided but not functional.
- 4 Sprinklers system is provided but not functional.
- 5 Internal hydrant is provided but not functional.
- 6 Terrace level fire pump is provided but not functional & not an auto mode.
- 7 Terrace level fire water tank capacity of 15000ltr is provided against the requirement of 20,000ltr, and also to inform the fire water tank is being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only

Keeping in view of above renewal of Fire Safety Certificate cannot be considered at this stage & rejected. Applicant is requested to rectify the above mentioned shortcomings under intimation to this department: till such time running of eating house is at your own risk & responsibility.

Yours faithfully

(Aul Garg)  
Director  
Ph: 011-23414000  
9c 6 4/4

Copy to:-

1. The Commissioner Municipal Corporation of Delhi: to ensure the occupancy as detailed above deviation and if any.
2. Online ID No. 2025031803835 dated 18.03.2025.