



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE, NEW DELHI - 110001

No: F6/DFS/MS/EH/SZ/2025/124

Dated: 09 / 04 / 2025

FIRE SAFETY CERTIFICATE

Certified that the M/s M. G. Bakers Pvt. Ltd. (NIK Bakers) located at Ground Floor, M-25, Greater Kailash-2, New Delhi- 110048, comprised of Basement + Ground + 02 upper floors but restaurant is running at ground floor was granted FSC by this department vide letter no. F.6/DFS/MS/EH/2022/SZ/190 dated 30.06.2022. Now, the building/premises was re-inspected by the officer concerned of this department on 05.04.2025 in presence of Mr. Mohit (Manager) and observed that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010. Accordingly, the premises is fit for occupancy class (Group D) "Assembly Building", (restaurant running at ground floor only) with effect from09./04./2025 and valid upto 31.03.2028 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on09/04/2025.....at New Delhi by


 9/4/2025
(Virendra Singh)
 Chief Fire Officer
 For Director
 Delhi Fire Service

Copy to:-

1. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi. w.r.to ID No. 2025031703692 dated 17.03.2025.
2. The Licensee, M/s M. G. Bakers Pvt. Ltd. (NIK Bakers) at Ground Floor, M-25, Greater Kailash-2, New Delhi- 110048.

Conditions for the validity of fire safety certificate

1. This FSC is valid for ground floor (restaurant) only.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

INSPECTION REPORT

| | | | | |
|------|--|--|------------------|-----------------|
| 1 | Name & address of the building | M/s M G Bakers Pvt. Ltd. (NIK Bakers) at M-25, Greater Kallash-II, New Delhi - 110048. | | |
| 2 | Building is comprised of | (Basement + Ground + 02 upper floors) Restaurant at ground floor only | | |
| 3 | Type of occupancy | "Assembly Building" (Ground-D) (Eating House) | | |
| 4 | Type of case | Renewal | | |
| 5 | Details of previous FSC | F.6/DFS/MS/EH/2022/SZ/190 dated 30.06.2022 | | |
| 6 | Fire safety direction letter no. | Nil | | |
| 7 | Date of inspection | 05.04.2025 | | |
| 8 | Name of the inspecting officers | ADO (SPM) | | |
| 9 | Name of the designation of officer from the building side | Mr. Mohit (Manager) | | |
| 10 | Year of construction | 2006 | | |
| 11 | Applicant's letter no. | Online application no. 2025031703692 dated 17.03.2025 | | |
| S.No | Minimum Standards on fire Prevention and fire safety requirements U/R 33 | Old NOC requirements | Provided at Site | Remarks MR/ NMR |
| 1 | Access To Building: | | | |
| | Road width | 06 mtrs. | Provided | MR |
| | Gate width | NA | NA | NA |
| | Width of internal road | NA | NA | NA |
| 2 | Number, Width, Type and Arrangement of Exits: | | | |
| | Ground Floor | | | |
| A | Number of staircases | | | |
| a | Upper floor | NA | NA | NA |
| b | Basement | NA | NA | NA |
| B | Width of staircases | | | |
| a | Upper floor | NA | NA | NA |
| b | Basement | NA | NA | NA |
| C | Protection of exits | | | |
| a | Fire check door | NA | NA | NA |
| b | Pressurization | NA | NA | NA |
| D | No. of continuous staircases to terrace | Required | Provided | MR |
| E | Width of corridor | NA | NA | NA |
| F | Door size | 2.0 m & 1.50 m | 2.0 m & 1.5 m | MR |
| 3 | Compartmentation: | | | |
| A | Fire check door | NA | NA | NA |
| B | Sealing of electrical shafts | NA | NA | NA |
| C | Fire rating of shaft door | NA | NA | NA |
| D | Water curtain | NA | NA | NA |
| E | Fire dampers | NA | NA | NA |
| 4 | Smoke Management System: | | | |
| A | Upper floors | 12 ACPH | Exhaust fan | MR |
| B | Basements | NA | NA | NA |

| | | | | | |
|----|--|--------------------------------|----------|------------------|----|
| 5. | Fire Extinguisher: | | | | |
| | A | Total numbers | 06 nos. | 06 nos. | MR |
| | B | Types | ABC& Co2 | Provided | MR |
| | C | ISI marking | Required | Provided | MR |
| 6 | First-Aid-Hose Reels: | | | | |
| | A | Total numbers on each floor | 01 no. | Provided | MR |
| | B | Length of hose reel hose | 30 mtr. | Provided | MR |
| | C | Nozzle diameter | 05 mm | Provided | MR |
| 7 | Automatic Fire Detection And Alarming System: | | | | |
| | A | Type of detectors | NA | Smoke type | NA |
| | B | Location of main panel | NA | Ground floor | NA |
| | C | Location of repeater panel | NA | NA | NA |
| | D | Alternate source of power | NA | Provided | NA |
| | E | Hooters Location | NA | Near entry /exit | NA |
| 8 | MOEFA: | | Required | Provided | MR |
| 9 | Public Address System: | | NA | NA | NA |
| 10 | Automatic Sprinkler System: | | | | |
| | A | Basement | NA | NA | NA |
| | B | Upper floors | NA | NA | NA |
| | C | Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants: | | | | |
| | A | size of riser/down-comer | 100 mm | Provided | MR |
| | B | Number of hydrants per floor | 01 no. | Provided | MR |
| | C | Hose box | 01 no. | Provided | MR |
| 12 | Yard Hydrants: | | | | |
| | A | Total number of hydrants | NA | NA | NA |
| | B | Hose box | NA | NA | NA |
| 13 | Pumping Arrangements: | | | | |
| | A | Ground level | | | |
| | a) | Discharge of main pump | NA | NA | NA |
| | b) | Head of main pump | NA | NA | NA |
| | c) | Number of main pumps | NA | NA | NA |
| | d) | Jockey pump out put | NA | NA | NA |
| | e) | Jockey pump head | NA | NA | NA |
| | f) | Standby pump out put | NA | NA | NA |
| | g) | Standby pump head | NA | NA | NA |
| | h) | Auto starting /manual stopping | NA | NA | NA |
| | i | Pump House Access | NA | NA | NA |
| | B | Terrace level | | | |
| | a) | Discharge of pump | 450 LPM | Provided | MR |
| | b) | Head of the pump | 40 m | Provided | MR |
| | c) | Power supply | Required | Provided | MR |
| | d) | Auto starting of pump | Required | Provided | MR |

| | | | | |
|----|---|------------------------------|--------------|----------|
| 14 | Captive Water Storage For Fire Fighting: | | | |
| | A | Underground tank capacity | NA | NA |
| | B | Draw-off connection | NA | NA |
| | C | Fire service inlet | NA | NA |
| | D | Access to tank | NA | NA |
| | E | Overhead tank capacity | 20,000 ltrs. | Provided |
| 15 | Exit Signage: | | Required | Provided |
| 16 | Provision of Lifts: | | | |
| | A | Pressurization of lift shaft | NA | NA |
| | B | Pressurization of lift lobby | NA | NA |
| | C | Communication in lift car | NA | NA |
| | D | Firemen's grounding switch | NA | NA |
| | E | Lift signage | NA | NA |
| 17 | Standby Power Supply: | | Required | Provided |
| 18 | Refuge Area: | | | |
| | A | Total area | NA | NA |
| | B | Location | NA | NA |
| 19 | Fire Control Room : | | | |
| | A | Detector system panel | NA | NA |
| | B | Flow switch panel | NA- | NA |
| | C | Pa system panel | NA | NA |
| | D | Battery backup | NA | NA |
| | E | Building floor plans | NA | NA |
| 20 | Special Fire Protection Systems For Protection of Special Risks, If Any: | | NA | NA |

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. F.6/DFS/MS/EH/2022/SZ/190 dated 30.06.2022 is recommended to be renewed (restaurant at ground floor only) under Rule 35 of the Delhi Fire Service Rules 2010.

Accordingly, DFA is put up for approval and signature please.

Sumit Kumar
07/04/2025

Signature of the Inspecting Officer
Name Sumit Kumar
Designation ADO (SPM)

DO (SD) *[Signature]* 21/4/25
CFO (MS) *[Signature]*
8/4/2025
Director *[Signature]*
01/05/2025
ADP/SPM

F.T. letter is put up for signature, please.

C.F.O. 1

[Signature]
9/4/2025

MS cell

Sumit Kumar
09/04/2025
ADP/SPM P.F.O.