

C-23

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F6/DFS/MS/School/2025/SZ/ 519

Dated: 10/06/2025

To,

The Owner/occupier,  
St. Michell Public School,  
B Block, Bindapur, Janak Puri, New Delhi-110059.

**Sub: - Regarding issuance of "FSC" from fire safety point of view in r/o St. Michell Public School located at B Block, Bindapur, Janak Puri, New Delhi-110059.**

Sir,


Please refer to your letter No. Nil, dated 15.04.2025, on the subject cited above. In this connection, it is to inform you that officer concerned of this department inspected the school building on dated 26.05.2025 in the presence of Sh. R.K. Sharma, to verify the fire safety arrangements in accordance with the rules.

At the time of inspection, it was observed that the running at lower ground, upper ground, first, second & third floor and fourth floor is completely closed, and following shortcomings observed: -

1. First aid hose reel found provided but not functional.
2. Terrace fire pump of 220 LPM found provided against requirement of 450 LPM.
3. Overhead water storage tank of 5,000 ltrs. found provided against requirement of 10,000 ltrs.
4. Exit signage's are found not provided.
5. Sanctioned plan/As built plan of the school building should be provided with section elevation from registered architect.

In view of above, fire safety certificate cannot be issued at this stage. Therefore, you are requested to rectify the above said shortcomings under the intimation to this department for further necessary action in the matter and running school in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier.

Yours faithfully

  
(Virendra Singh)  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

: - for necessary action please.