

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/2025/736

Dated: 18 09/2025

To

The Principal,  
Convent of Jesus and Merry School,  
01, Bangla Sahib Road, New Delhi.

Sub: Regarding issuance /Renewal of FSC in r/o Middle block of convent of Jesus and Merry School  
Situated at 01 Bangla Sahib Road, New Delhi.

Sir,

This has reference to your Mail id<cjm.delhi@yahoo.com> dated 22.08.2025, on the subject cited above. In this regard, it is to inform you that the site was inspected by officer concerned of this department on 09.09.2025 in the presence of Principal and the shortcoming issued earlier have not been complied.

1. Alternate staircase of .75 m is not provided in the basement.
2. Fire check door is not provided in the basement.
3. Further, use of basement shall be ensured as per BBL concerned. However, at present library is running in basement.

In view of above, fire safety certificate (FSC) cannot be issued to the said block at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest under intimation to this department for further consideration in the matter.

Yours faithfully,

  
17/9/2025

(Virendra Singh)  
Chief Fire Officer

