



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2025/ 1037

Dated: 21/08/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Milli Model School located at D-309, Dawat Nagar, Abdul Fazal Enclave, Jamia Nagar, New Delhi-25, comprised of Comprised of Two Block: 1st Block- Ground + 01 upper floor, 2nd Block- Ground floor, was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2022/SZ/65 dated 24.01.2022. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 05.08.2025 in the presence of Mrs. Samina Begam, Principal and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no. 3298 to 3398 dated 01.03.2011 issued by the Director of Education and the building is fit for occupancy of Group B "Educational Building" with effect from 21/08/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 21/08/2025 at New Delhi by


(Virendra Singh)
Chief Fire Officer

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.
2. The Principal, M/s Milli Model School located at D-309, Dawat Nagar, Abdul Fazal Enclave, Jamia Nagar, New Delhi-25.

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	M/s Milli Model School located at D-309, Dawat Nagar, Abdul Fazal Enclave, Jamia Nagar, New Delhi-25.		
2	Building is comprised of	Comprised of Two Block: 1 st Block- Ground + 01 upper floor 2 nd Block- Ground floor		
3	Type of occupancy	Group B –Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2022/SZ/65 dated 24.01.2022		
6	Fire safety direction letter no.	F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011		
7	Date of inspection	05.08.2025		
8	Name of the inspecting officers	Rajesh Kumar Shukla, ADO (M. Road)		
9	Name of the designation of officer from the building side	Mrs. Samina Begam, Principal		
10	Year of construction	1989		
11	Applicant's letter no.	Outdoor diary no. 4086 dated 24.07.2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement as per Rules 35 (6)	Provided at site	Remarks MR/NMR
1	Access to Building:			
	A Road width	Accessibility	9.0 m	MR
	B Gate width	NA	NA	NA
	C Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	2 nos.	3 nos.	MR
	b Basement	NA	NA	NA
	B Width of staircases			
	a Upper floor	1 staircase of 1.5 mtrs or if main staircase width is < 1.5 mtrs an additional staircase of 0.75 mtrs width is required.	1.50 m, 1.37 m & 1.37 m to 1.52 m	MR
	b Basement	NA	NA	NA
	C Protection of exits			
	a Fire check door	NA	NA	NA
	b Pressurization	NA	NA	NA
	D No. of continuous staircases to terrace	Required	2 nos.	MR
	E Width of corridor	1.5 mtrs	Provided	MR
	F Door size	1.0 mtrs for class room	Provided	MR
3	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	NA	NA	NA
	C Fire rating of shaft door	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	Smoke Management System:			
	A Basement	NA	NA	NA
	B Upper floor	NA	NA	NA
5.	Fire Extinguisher:			
	A Total numbers	Required	15 nos.	MR
	B Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C ISI marking	Required	Provided	MR
6	First-Aid-Hose Reel:			
	A Total numbers of each floor	NA	NA	NA
	B Length of hose reel hose	NA	NA	NA
	C Nozzle diameter	NA	NA	NA

7	Automatic Fire Detection and Alarming System:			
	A	Type of detectors	NA	NA
	B	Location of main panel	NA	NA
	C	Location of repeater panel	NA	NA
	D	Alternate source of power	NA	NA
	E	Hooters	NA	NA
8	MOEFA:		NA	NA
9	Public Address System:		NA	NA
10	Automatic Sprinkler System:			
	A	Basement	NA	NA
	B	Upper floor	NA	NA
	C	Sprinkler above false ceiling	NA	NA
11	Internal Hydrants:			
	A	Size of riser/down-comer	NA	NA
	B	Number of hydrants per floor	NA	NA
	C	Hose box	NA	NA
12	Yard Hydrants:			
	A	Total number of hydrants	NA	NA
	B	Hose box	NA	NA
13	Pumping Arrangements:			
A	Ground level			
	a)	Discharge of main pump	NA	NA
	b)	Head of main pump	NA	NA
	c)	Number of main pumps	NA	NA
	d)	Jockey pump out put	NA	NA
	e)	Jockey pump head	NA	NA
	f)	Standby pump out put	NA	NA
	g)	Standby pump head	NA	NA
	h)	Auto starting /manual stopping	NA	NA
	i)	Pump house access	NA	NA
B	Terrace Level			
	a)	Discharge of pump	NA	NA
	b)	Head of the pump	NA	NA
	c)	Power supply	NA	NA
	d)	Auto starting of pump	NA	NA
14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	NA	NA
	B	Draw-off connection	NA	NA
	C	Fire service inlet	NA	NA
	D	Access to tank	NA	NA
	E	Overhead tank capacity	NA	NA
15	Exit Signage:		Required	Provided
16	Provision of Lifts:			
	A	Pressurization of lift shaft	NA	NA
	B	Pressurization of lift lobby	NA	NA
	C	Communication in lift car	NA	NA
	D	Firemen's grounding switch	NA	NA
	E	Lift signage	NA	NA
17	Standby Power Supply:		NA	NA
18	Refuge Area:			
	A	Total area	NA	NA
	B	Location	NA	NA

2/10

M/s Milli Model School located at D-309, Dawat Nagar, Abdul Fazal Enclave, Jamia Nagar, New Delhi-25.

19 Fire Control Room:				
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	PA system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	NA		NA

Meeting Requirement (MR), Not Meeting Requirement (NMR), Not Applicable (NA), Provided but Not Functional (PNF), Not Provided (NP).

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in Directorate of Education Circular no. 3298 to 3398 dated 01.03.2011, the FSC issued vide letter no. F6/DFS/MS/School/2022/SZ/65 dated 24.01.2022 is recommended to be renewed.

Signature of the Inspecting Officer

Name Rajesh Kumar Shukla

Designation ADO (M. Road)

DO (SD)

[Signature]
5/8/20

CFO
16/8/2025

Principal Director

CFO to Secy.

[Signature]
12/8/25

[Signature]
20/8/2025

ADO (M. Rd.)

FI is put up

[Signature]

CFO
20/8/2025

MS