



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/Cinema/2025/NDZ/819

Dated: 20/05/2025

To,

Mr. Tapan Kumar,
S.D.M (Shahara),
A-Block, 1st floor, D.C. Office Complex,
Nand Nagri, Delhi – 110093.

Subject: - Annual Joint Inspection of Cinema building of M/s Multiplex Miraj Entertainment Limited at 2nd floor 813/1, Vikas Cine Mall, G.T. Road, Shahdara, Delhi - 110032.

Reference to the above quoted letter received from SDM (Shahara), on the subject cited above. In this connection, it is submitted that the cinema hall building was inspected by the officer concerned of this department on 10-05-2025 and the time of inspection, Mr. Abhishek (Manager) was also present.

During the course of inspection the existing fire protection arrangements, such as overhead/underground water storage tank (25,000 & 2,00,000 litres), fire hydrant, hose reels, fire pump, portable fire extinguishers, manual operated fire alarm system, P.A. system, exit signs, emergency lights and means of escape etc. Were operated and the performance found satisfactory at the time of inspection. However, the following directives must be strictly adhered to:

1. All the firefighting arrangements as provided in the cinema building shall always be kept in good repairs as seen during the inspection.
2. All the employees shall be acquainted with the use and maintenance of fire protection arrangements provided in the cinema building.
3. Means of escape shall not be kept blocked or bolted from outside and shall be easily open able by guest in the event of any emergency.
4. The fire suppression/protection arrangement provided in the premises are the minimize losses if maintained properly.
5. Basement shall be used as condition of "Building Bye Laws".
6. Any loss of property/life due to non-functional of fire safety measures/equipment's shall be responsibility of management solely.
7. Cinema slides providing information on fire protection arrangements and means of escape shall be shown before the commencement of each cinema show.
8. Any lapse rendering to non-functional of fire protection arrangements/equipment's shall be at risk and responsibility of the licensee.

Any lapse rendering to non-functional of fire protection arrangements/equipment's shall be at risk and responsibility of the license.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to: -

1. The Manager, M/s Multiplex Miraj Entertainment Limited at 2nd floor 813/1, Vikas Cine Mall, G.T. Road, Shahdara, Delhi - 110032.