

C48

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2021/EH/08

Dated: 03/01/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Miss Doozy (A Unit of Ascent Enjoy Pvt. Ltd.) located at Ground Floor, Shop No. 19, 20 & 21 Savitri Cinema Complex, DLF Center, Greater Kailash Part-II, New Delhi-110048, in a building comprised of Basement + Ground + 3 Upper Floors was issued FSC vide letter No. F6/DFS/MS/EH/2021/SZ/376 dated 23/12/2021. The premises was inspected by the officer concerned of this department on 18/12/2024 in the presence of Mr. Prem Shankar (Manager) and found that premises have deem complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly" Group D (At Ground Floor) with effect from 03/01/2025 for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 03/01/2025 at New Delhi by.

(Atul Garg)  
Director  
Delhi Fire Service

Copy to:

1. The Joint Commissioner Police, Licensing, 1<sup>st</sup> Floor, PS, Defence Colony, N Delhi. (w.r.t. online ID No. **2024120417618** dated 07.12.2024)
2. The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.

**Condition for the validity of fire safety certificate:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. This certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement if any shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

# INSPECTION REPORT

1. Name & address of the building: Miss Doozy (A Unit of Ascent Enjoy Pvt. Ltd.) Located at Ground Floor, Shop No. 19, 20 & 21 Savitri Cinema Complex, DLF Center, Greater Kailash Part – II, New Delhi - 110048.
2. Type of Occupancy : Assembly "D" Restaurant
3. Type of Case : Renewal (**Building comprised of B+G + 3 upper floor and Restaurant running at Ground Floor**)
4. Details of previous NOC : F6/DFS/MS/EH/2021/SZ/376 dated 23/12/2021  
(Issued to Building **F6/DFS/MS/Cinema/2023/SZ/312 Dt. 30/06/2023**)
5. Fire Safety directives L. No. : F6/DFS/MS/BP/Cinema/2000/1676 dt. 19/09/2000
6. Date of inspection : 18-12-2024
7. Name of the Inspecting Officer : Sh. Uday vir Singh ADO (DWK)
8. Name and designation of Officer  
from the building side : Mr. Prem Shankar (Manager)
9. Year of Construction : 1976
10. Applicant's letter No. : 2024120417618 dated 07-12-2024

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/8, N/9 & N/10	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Eating house Within Savitri Cine Complex	Provided NA NA	MR NA NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases <ul style="list-style-type: none"> <li>Upper floors</li> <li>Basements</li> </ul> b. Width of staircases <ul style="list-style-type: none"> <li>Upper floors</li> <li>Basements</li> </ul> c. Protection of exits <ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul> d. No of continuous staircase to terrace           e. Width Of Corridor           f. Door Size	NA NA NA NA NA NA NA 1.5m X2	Restaurant at GF Only NA NA NA NA NA NA Provided	NA NA NA NA NA NA NA MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	Required NA NA NA NA	Provided NA NA NA NA	MR NA NA NA NA
4.	Smoke managements System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	NA 12 ac per hour	NA Provided in Kitchen	NA MR



5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	Required	10 Nos.	MR
		ABC /CO2	ABC	MR
		ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA	Provided	NA
		NA	Provided	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Ground Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
		NA	Provided	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	Required	Provided	MR
		01 No.	Provided	MR
		Required	Provided	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		450 lpm,	900 lpm	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR

14	Captive water Storage for fire fighting			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	20,000 litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	Provided	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	Provided	NA
	➤ Battery backup	NA	Provided	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC fire extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter F6/DFS/MS/SZ/2021/299 dated 25/10/2021 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer  
Name *Abhinav Singh*  
Designation *AD/DWP*

*AD/DWP*  
*AD/DWP*

*Pl. see previous inspection at N-7409.*

*[Signature]*  
*AD/DWP*

*Sir, at the time of inspection the representative of hotel was not available however the restaurant have separate entry/exit & fire fighting system exclusively*