

C/88

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.


No.F.6/DFS/MS/Hospital/2025/SZ/ 455

Dated: 02/09/2025

FIRE SAFETY CERTIFICATE

Certified that the MKW Hospital located at J-Block, Community Centre, Rajouri Garden, New Delhi- 110027, is comprised of basement, ground plus three upper floors owned/occupied by Shri Mai Kamli Wali Jan Kalyan Charitable Hospital, was issued FSC by this department vide letter No. F.6/DFS/MS/Hospital/2020/SZ/428 dated 22/10/2020, The Hospital building was re-inspected by the officer concerned of this department on dated 18.08.2025 in the presence of Dr. Ashish Bawa, and found that hospital building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class Group-C "Institutional Building" wef 02/09/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed below.

Issued on 02/09/2025 at New Delhi by.


 (Virendra Singh)
 Chief Fire Officer

Copy to: -

1. The Commissioner, MCD, Delhi: for information regarding use of basement and to ensure the occupancy as detailed above and deviation, if any.
2. The Medical Superintendent, MKW Hospital located at J-Block, Community Centre, Rajouri Garden, New Delhi- 110027.
3. The MS, Nursing Homes, Directorate of Health Services, Govt. of NCT of Delhi, S-1, 3rd Floor, School Block, Shakarpur, Delhi-110092.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. Basement shall be used as per the building bye laws.
7. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : MKW Hospital, J-Block, Community Centre, Rajouri Garden, New Delhi-110027
2. Building comprised of : Basement, ground plus three upper floors & few rooms along with lift room at terrace.
3. Type of Occupancy : Institutional (Hospital Building)
4. Type of Case : Renewal
5. Details of Previous NOC : F.6/DFS/MS/Hospital/2020/SZ/428 dated 22/10/2020
6. Fire Safety directives letter No : F6/DFS/MS/94/Hospital/1133 dated 01.08.1994
7. Date of inspection : 18.08.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Dr. Ashish Bawa
10. Year of Construction : 1994
11. Applicant's letter No. : letter No. 229/MKW/F/12 dated 25.07.2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC / BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 05 mtrs. N/A	12 mtrs 05 mtrs. N/A	M/R M/R N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	01 no. 01 no.	02 nos. 02 nos.	MR MR
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	Old case Old case	1.25 & 1.0 m 1.25 & .92 m	MR MR
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	Required N/A	Provided N/A	MR N/A
	d. No. of continuous staircases to terrace	Required	One	MR
	e. Width of Corridor	2.04	2.10 m	MR
	f. Door Size	Old case	1.0 m	M/R, old case
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	Required Required N/A N/A N/A	Provided Sealed N/A N/A N/A	MR M/R N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	Required Required	Provided Provided	MR MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	30 no.'s ABC/ CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One in each floor 30 m 5 mm	Provided Provided Provided	MR MR MR

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Required	Provided	MR
		N/A	Ground floor	M/R
		N/A	Ground floor	M/R
		Required	Provided	M/R
		N/A	In staircase	M/R
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm	Provided	MR
		One	Provided	MR
		One	Provided	MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		900LPM & 180 LPM	Provided	MR
		40 mtrs	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	35,000 ltrs.	35,000 ltrs.	M/R
		Required	Provided	MR
		Required	Provided	M/R
		Required	Provided	M/R
		12,500 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	Provided	N/A

MR M/R M/R	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:			
		N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Note: - As per affidavit submitted by Hospital management (placed at C- 83) that the hospital building comprised of basement, ground plus three upper floors, using basement (OPD), Ground floor (OPD, Casualty, Reception & Pharmacy, 1st floor (Ward, Laboratory) 2nd floor (Ward & NICU), 3rd floor (OT/ICU Complex) and no new construction has been carried out on the 4th floor.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the Fire Safety Certificate issued vide letter No. F.6/DFS/MS/Hospital/2020/SZ/428 dated 22/10/2020 is recommended to be renewed under rule 37, of the Delhi Fire Service Rules, 2010.

R. K. Yadav
18/8/2025

Signature of the Inspecting Officer

Name:-R.K. Yadav

Designation: - ADO (JKP)

DO (SW)

[Signature]
20/8/25

CFO *[Signature]*
22/01/2025

Principal Director

CFO to Dm
[Signature]

ADO (JKP) *[Signature]*