

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No: F.6/DFS/MS/MLCP/2025/SZ/ 155

Dated: 09/04/2025

To,

Executive Engineer (Elect.), WZ, MCD,
Old Zonal Office Building, Vishal Enclave,
Rajouri Garden, New Delhi- 110027.

Sub: - Regarding renewal of FSC in r/o Multi-Level Car Parking & Community Hall at Subhash Nagar, New Delhi-110027

Sir,

This has reference to your letter No. E.E.(E)/WZ/2024-25/D-1096 dated 07.02.2025, on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the premises/building on dated 28.03.2025 to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Divyanshu, AE (MCD). was present and it was observed that the building comprised of three tier basements, ground floor, Mezzanine floor, 1st floor & 2nd floor, and have following shortcomings were observed:

1. First aid hose reel provided but found not functional.
2. Hydrant system provided but found not functional.
3. Terrace level fire pump provided but found not functional in auto mode.
4. Underground pumps provided as per requirements but found not in working condition.
5. Exit Signes found removed at some places.
6. Good house-keeping should be provided.

In view of above shortcomings, the application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the above-mentioned shortcomings under intimation to this department for taking further necessary action in this matter, till such time operation of MLCP & Community Hall is at your own risk and responsibility.

Yours faithfully,


(Atul Garg)
Director
Delhi Fire Service
07/04/25