

C-21

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**


No.F.6 DFS/MS/School/2025/SZ/1291

Dated: 06/11/2025

FIRE SAFETY CERTIFICATE

Certified that the **Modern Public School** located at Vasant Kunj Enclave (A Block) New Delhi 110070 Comprised of Ground plus half upper floor owned/occupied by Modern Public School was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2022/SZ/492 Dt. 09/05/2022. The said premise was re-inspected by officer concerned of this department on 17/09/2025 in presence of Mrs. Sharda Dolare and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Directorate of Education circular F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01/03/2011 issued by Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class **"Educational Building Group - B"** with effect from 06/11/2025 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 06/11/2025 at New Delhi by


4/11/25
(A. K MALIK)
Dy. CFO (SOUTH ZONE)
DELHI FIRE SERVICE
o/c (u)

Copy to: -

1. Modern Public School located at Vasant Kunj Enclave (A Block) New Delhi 110070.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 54.

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/14

INSPECTION REPORT			
1	Name & Address of the Building	Modern Public School, Vasant Kunj Enclave (A Block) New Delhi 110070	
2	Type of Occupancy	Educational, Group-B (School)	
3	Building Comprised of	Ground plus Half Upper Floor	
4	Type of Case	Renewal	
5	Details of Previous NOC	F6/DFS/MS/School/2022/SZ/492 Dt. 09/05/2022	
6	Fire Safety Directives Letter No	F.16//Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011	
7	Date of Inspection	17-09-2025	
8	Name of the Inspecting Officers	Sh. Rajesh Kumar DO	
9	Name & Designation of Officers from the building side	Mrs. Sharda Dolare	
10	Year of construction	2010	
11	Applicant letter No.	DFS outdoor diary no 5634 dated 04/09/2025	
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	As per old NOC Requirement	Provided at Site
			Remarks MR/NMR
1	Access to Building.		
	• Road width	6 mtr	Provided MR
	• Gate width	4.5 mtr	Provided -NA-
	• Width of internal road	-NA-	-NA- -NA-
2	Number, width, type & arrangement of exits.		
	a) Number of Staircase		
	➤ Upper floors.	02 Nos	02 Nos MR
	➤ Basement floor.	-NA-	-NA- -NA-
	b) Width of Staircase		
	➤ Upper floors	1.50 m/0.75m	1.07 mtr each MR
	➤ Basement floor	-NA-	-NA- -NA-
	c) Protection of exits		
	➤ Fire check door	-NA-	-NA- -NA-
	➤ Pressurization	-NA-	-NA- -NA-
	d) No. of continuous staircase to terrace	01	01 MR
	e) Width of corridor	1.5m	1.5m MR
	f) Door size	1 mtr	1 mtr MR
3	Compartmentation.		
	• Fire check door.	-NA-	-NA- -NA-
	• Sealing of electrical shafts.	-NA-	-NA- -NA-
	• Fire rating of shaft door.	-NA-	-NA- -NA-
	• Water curtain	-NA-	-NA- -NA-
	• Fire dampers.	-NA-	-NA- -NA-
4.	Smoke Management system.		
	• Basement	-NA-	-NA- -NA-
	• Upper floors	-NA-	-NA- -NA-
5.	Fire Extinguishers.		
	• Total numbers	08 Required	08 Nos Provided MR
	• Types	ABC	ABC & Co2 Type MR
	• ISI Marking	ISI mark	Provided MR
6.	First Aid Hose Reels.		
	• Total numbers on each floor.	-NA-	01 Nos -NA-
	• Length of hose-reel hose.	-NA-	30m -NA-
	• Nozzle Diameter	-NA-	5mm -NA-
7	Automatic fire detection & alarming system.		

		-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	-NA-	-NA-	-NA-
11.	Internal Hydrants.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Size of Riser/Down-comer Number of Hydrant per floor Hose box. 	-NA-	-NA-	-NA-
12.	Yard Hydrants.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	-NA-	-NA-	-NA-
13.	Pumping arrangements.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting / Manual Stopping. Pump house access. Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- 225 LPM 25m NA Switch provided at GF	-NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA- -NA-
14.	Captive water storage for fire fighting.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- 2500 ltr	-NA- -NA- -NA- -NA- MR
15.	Exit Signage.	Provided	Provided	MR
16.	Provision of Lifts.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Total area Location 	-NA- -NA-	-NA- -NA-	-NA- -NA-
19.	Fire Control Room.	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> Detector system panel. 	-NA- -NA-	-NA- -NA-	-NA- -NA-


n/12

	<ul style="list-style-type: none"> Flow switch panel. PA system panel. Battery backup. Building floor plan. 	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standard on fire prevention and fire safety measures as required under the rules, the FSC issued vide letter no F6/DFS/MS/School/2022/SZ/492 Dt. 09/05/2022, renewal under rule 37 of the Delhi Fire Service rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name: Sh. Rajesh Kumar
 Design: Divisional Officer

DO (South)


28/10/25

CFO/

22/9/2025

Principal Director

Dy. CFO to Secy.

Dy. CFO (SZ)


24/10/25
A.K. MALIK

DO (SD)

28/10/25

Sir. F.T Letter is put up for Sign. Please

Dy CFO (SZ)


4/11/25
A.K. MALIK

M.S cell


3/11/2025