



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 470

Dated: 30/05/2025

To

The Principal,
Modern International School,
Sector-19, Phase -1, Dwarka,
New Delhi-110075

Sub: **Renewal of Fire Safety Certificate in r/o Modern International School located at Sector-19, Phase -1, Dwarka, New Delhi-110075**

Sir,

Please refer to your letter No. Nil dated 22/04/2025, received in this department vide outdoor diary No 1132 dated 29/04/2025, on the subject cited above. In this connection, it is to inform you that the said premise was visited by the officer concerned of this department on 09/05/2025 in the presence of Mr. A.K Sinha to verify the availability and operability of the fire prevention and fire safety measures. During the inspection, shortcomings observed are as below.

1. First aid hose reel provided found non-functional and not covering entire area.
2. Terrace level fire pumps found non-functional.
3. Overhead water storage for firefighting found empty.
4. Exit signage found removed at some locations.
5. Use of basement floor for school activities & swimming pool shall be got verified from the authority concerned.

In view of above, application for renewal of fire safety certificate is rejected. You are advised to submit para-wise compliance of the shortcomings for further action in the matter. The occupancy of the building in the absence of valid Fire Safety Certificate shall be at the risk and liability of the school management/owner/occupier.

Yours faithfully,


(ATUL GARG)
DIRECTOR

Ph. 011-23414000

01/06

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054