



C/30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No.F.6/DFS/MS/Hospital/2025/NDZ/ 390

Dated: 19/08/2025

To,

The Director,  
M/s Monga Medical Centre,  
(A Centre For Personalised Medical Care)  
J-10, Krishna Nagar,  
Delhi -110051

**Subject: -Regarding issuance of Fire Safety Certificate in r/o M/s Monga Medical Centre (A Centre For Personalised Medical Care) J-10, Krishna Nagar Delhi 110051.**


Sir,

This is in reference to your letter no. nil dated 08/07/2025 on the subject cited above. In this connection, the premises have been re-inspected by the officer concerned of this department on dated 02/08/2025 in presence of Dr. V.K. Monga and observed that building comprised of **Basement + stilt + Ground plus three upper floor. Following shortcomings were observed during the time of inspection.**

1. Corridor width of 2.10 meters provided against the requirement of width 2.40 meters.
2. Overhead tank of capacity 10,000 liters shall be required exclusively for firefighting. This is overhead tank is connected to domestics use also, which is not allowed.

**In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected.** The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

 18/8/2025

o/c (VIRENDRA SINGH)  
CHIEF FIRE OFFICER

Copy to:-

1. The Director, M/s Monga Medical Centre located at Plot No. J-10, Krishna Nagar, Delhi-110051
- 2.. The Medical Superintendent, Nursing Homes, Directorate General of Health Services, Govt. of NCT of Delhi, 3<sup>rd</sup> floor, Delhi. Dispensary Building, S-1, School Block, Shakarpur, Delhi-110092