



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001




No F 6 / DFS / MS / 2025 / School / WZ / 882

Dated: 11/07/2025

FIRE SAFETY CERTIFICATE

Certified that the **Montfort School** located at **Ashok Vihar, Phase-1, Delhi-110052** comprised of **04 Blocks (02 Blocks- Ground plus three upper floors each, 01 Block- Ground plus two upper floors, all three blocks interconnected & 01 New Block- Ground plus three upper floors)** was issued FSC by this department vide letter No F6/DFS/MS/School/WZ/2022/511 dated 12.05.2022. The premise was re-inspected by the officer concerned of this department on 05.06.2025 in the presence of **Brother Joy Thomas (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirement under rule 33 of the Delhi Fire Service Rule, 2010 and that the building/ premise is fit for occupancy **Group B Educational** with effect from ...11.07.2025... for a period of **three years** in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40, subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on11.07.2025..... at New Delhi, by


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service
012A

Copy to :-

1. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Montfort School located at Ashok Vihar, Phase-1, Delhi-110052.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Monfort School located at Ashok Vihar Phase-1, Delhi- 110052.
2. Type of Occupancy : Educational
3. Building Comprised of : 04 Blocks (02 Blocks - G+3 each, 01 Block- G+2 all three blocks are Interconnected) and (01 New Block - G+3).
4. Type of Case : Renewal
5. Details of Previous NOC : F6/DFS/MS/School/WZ/2022/511 Dated- 12/05/2022
6. Fire Safety directives letter No : F6/DFS/MS/WZ/2020/396 Dated- 23/04/2020
F6/DFS/MS/BP/98/564 Dated- 18/03/1998
F6/DFS/MS/BP/2011/541 Dated- 25/03/2011
7. Date of inspection : 05/06/2025
8. Name of Inspecting Officer : R.K.Sinha, ADO (BW)
9. Name and designation of officers
From the building side : Brother Joy Thomas (Principal)
10. Year of Construction : 2007 as per N-17
11. Applicant's letter No. : E Mail id dated 12/05/2025

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rules 2010	Provided at site	Remarks MR/NMR
1.	Access to building			
	Road width	6 m	Provided	MR
	Gate width	Accessible	Provided	MR
	Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	Number of staircases			
	Upper Floors	02 in each block	Provided	MR
	Basements	NA	NA	NA
	Width of staircases			
	Upper Floor	1.50 m each and 1.5 m & 1.2 m for new block	BL-1 = 1.45 m & 1.46 m BL-2 = 2 × 1.5 m BL-3 = 1.38 m & 1.40 m BL-4 (New Block) = 2 × 1.5 m	MR (old case)
	Basements	NA	NA	NA
	Protection of exits			
	Fire check door	NA	NA	NA
	Pressurization	NA	NA	NA
	No. of continuous staircases to terrace	01	Provided	MR
	Width of Corridor	1.5 m	Provided	MR
	Door Size	1 m	1.15 m & 0.90 m	MR(old case)
3.	Compartmentation			
	Fire check door	NA	NA	NA
	Sealing of electrical shafts	NA	NA	NA
	Fire Rating of shaft door	NA	NA	NA
	Water Curtain	NA	NA	NA
	Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	Basements	NA	NA	NA
	Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	Total numbers	48 Nos.	Provided	MR
	Types	ABC/Co2 Type	Provided	MR
	IS marking	Required	Provided	MR
6.	First-Aid Hose Reels			
	Total numbers on each floor	01 in each block	Provided	MR
	Length of hose reel hose	30 m	Provided	MR
	Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	Type of detectors	NA	NA	NA

	Location of Main Panel	NA	NA	NA
	Location of Repeater Panel	NA	NA	NA
	Alternate source of power	NA	NA	NA
	Hooters' Location	NA	NA	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			NA
	Basement	NA	NA	NA
	Ground Floor	NA	NA	NA
	Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			MR
	Size of riser/down-comer	Required	Provided	MR
	Number of hydrants per floor	Required	Provided	MR
	Hose Box	Required	Provided	MR
12.	Yard Hydrants			NA
	Total number of hydrants	NA	Provided	NA
	Hose Box	NA	Provided	NA
13.	Pumping Arrangements			
	Ground Level			NA
	Discharge of main Pump	NA	NA	NA
	Head of Main pump	NA	NA	NA
	Number of main pumps	NA	NA	NA
	Jockey Pump out put	NA	NA	NA
	Jockey pump head	NA	NA	NA
	Standby Pump out put	NA	NA	NA
	Standby Pump Head	NA	NA	NA
	Auto Starting/Manual Stopping	NA	NA	NA
	Pump House Access	NA	NA	NA
	Terrace level			MR
	Discharge of pump	450 lpm & 180 lpm	Provided	MR
	Head of the pump	40 m	Provided	MR
	Power Supply	Required	Provided	MR
	Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	Underground tank capacity	NA	NA	NA
	Draw-off connection	NA	NA	NA
	Fire service inlet	NA	NA	NA
	Access to tank	NA	NA	NA
	Overhead Tank capacity	10,000 ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	Pressurization of Lift Shaft	NA	NA	NA
	Pressurization of Lift lobby	NA	NA	NA
	Communication In lift Car	NA	NA	NA
	Fireman's Grounding Switch	NA	NA	NA
	Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	Total Area	NA	NA	NA
	Location	NA	NA	NA

Control Room

Detector System Panel	NA	NA	NA
Flow Switch Panel	NA	NA	NA
PA System Panel	NA	NA	NA
Battery backup	NA	NA	NA
Building Floor Plans	NA	NA	NA
0. Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The management had rectified the shortcomings issued vide letter no. F6/DFS/MS/School/WZ/2022/511 dated 12/05/2022.

Note: One resident block comprised of Ground plus three upper floors & one swimming pool were also seen in the premises.

Keeping in view of deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, it is recommended to renew the Fire Safety Certificate issued vide letter no. F6/DFS/School/WZ/2022/511 dated 12/05/2022 under rule 37 of Delhi Fire Service Rules, 2010.

Signature of Inspecting Officer
Name : Rajeev Kumar Sinha
Designation : ADO/B.W.

DCFO/62-NW
Dated...06/06/25

~~Dy Cfo (W2)~~
~~6/6~~

~~Cfo~~ ~~Ving~~
~~6/6/2025~~

~~Dy Cfo (W2)~~

~~02/07/2025~~

~~ADO (Banana)~~ Dr. FT letter in support of signature

DCFO/12-NW
Dated...02/07/2025

~~Cfo (H2)~~ ~~Ving~~

~~MS call~~

~~ADO (B.W.)~~
~~3/7/25~~