

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/Hospital/2025/SZ/ 275

Dated: 29/05/2025

FIRE SAFETY CERTIFICATE

Certified that the **Mother & Child Block**, Masjid Moth, AIIMS, Complex, New Delhi-110029, comprised of Three tier Basement, Ground + 08 upper floors & service floor between 2nd & 3rd Floor, owned/occupied by All India Institute of Medical Sciences, was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/Hospital/2021/SZ/145 dated 24/02/2021. The premise was re-visited by the officer concerned of this department on 17/05/2025 in the presence of Sh. Pardeep Kumar Executive (Electrical) and found that the said premises have deemed complied with fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the said building/premises is fit for occupancy class "**Institutional, Group-C**" (Hospital) with effect from 29/05/2025 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 29/05/2025 at New Delhi by


(ATUL GARG)
DIRECTOR
Ph. 011-23414000

Copy to: -

1. Col. Digvijay Singh, Chief Security Officer, Administrative Block, AIIMS Complex, New Delhi-110029

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of firefighting system.
4. Basement shall be used strictly in accordance with Building Bye-Laws.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on www.dfs.delhigovt.nic.in

N-18

INSPECTION REPORT

1	Name & Address of the Building	Mother & Child Block, Masjid Moth, AIIMS, Complex, New Delhi-110029		
2	Type of Occupancy	Institutional Building "Group -C" (Hospital)		
3	Building Comprised of	Three tier Basement, Ground + 08 upper floors & service floor between 2 nd & 3 rd Floor which is approved in the drawings		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Hospital/2021/SZ/145 dated 24/02/2021		
6	Fire safety directives letter No	F6/DFS/MS/BP/2013/206 dated 23/07/2013		
7	Date of Inspection	17/05/2025		
8	Name of the Inspecting Officers	ADO (SJ)		
9	Name & Designation of Officers from the building side	Sh. Pardeep Kumar, Executive (Electrical)		
10	Year of construction	2019-20		
11	Applicant letter No.	Through e-mail dated 17/04/2025		
S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirement Old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	20 mtr	Provided	MR
	• Gate width	6 mtr	Provided	MR
	• Width of internal road	6 mtr	Provided	MR
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	➤ Upper floors	06 Nos	06 Nos	MR
	➤ Basement floor	08 Nos	08 Nos	MR
	b. Width of Staircase			
	➤ Upper floors	02 mtr	2m x 6nos	MR
	➤ Basement floor	2m & 1.50m	2m x 7 & 1.50m x 1	MR
	c. Protection of exits			
	➤ Fire check door	Required	Provided	MR
	➤ Pressurization	Required	Provided	MR
	d. No. of continuous staircase to terrace	05 Nos	06 Nos	MR
	e. Width of corridor	2.40m	2.40m	MR
	f. Door size	2 mtr	2 mtr	MR
3	Compartmentation.			
	• Fire check door.	Required	Provided	MR
	• Sealing of electrical shafts.	Required	Provided	MR
	• Fire rating of shaft door.	Required	Provided	MR
	• Water curtain	Required	Provided	MR
	• Fire dampers.	Required	Provided	MR
4.	Smoke Management system.			
	• Basement	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers.			
	• Total numbers	16 Per Floor	200 Nos	MR
	• Types	ABC/CO ₂ /W.CO ₂	Provided	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor.	Hose Reels	B3, B2=09, B1=08 & Upper Floors=06nos	MR
	• Length of hose-reel hose.		30m	MR
	• Nozzle Diameter		5mm	MR

N-17

7	Automatic Fire Detection and Alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	Smoke & Heat	Smoke & Heat	MR
		Ground Floor	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		All Areas	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors Sprinkler above false ceiling 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. 	150 mm	Provided	MR
		B3, B2=09, B1=08 & UFs=06nos	B3, B2=09, B1=08 & Upper Floors=06nos	MR
		B3, B2=09, B1=08 & UFs=06nos	B3, B2=09, B1=08 & Upper Floors=06nos	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	08 Nos	Provided	MR
		08 Nos	Provided	MR
13.	Pumping arrangements.	<i>Common fire-fighting pumps for Mother & Child, Geriatrics and Service Block</i>		
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting/Manual Stopping. Pump House Access Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	Hyd=2850 LPM Sprk=2850 LPM W/C=4500 LPM	Hyd=2850 LPM Sprk=2850 LPM W/C=4500 LPM	MR
		85m	Provided	MR
		Two	Provided	MR
		2 x 280 LPM	Provided	MR
		85m	Provided	MR
		2850 LPM	Provided	MR
		85m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		-NA-	450 LPM	-NA-
		-NA-	40m	-NA-
		-NA-	Provided	-NA-
		-NA-	Provided	-NA-
14.	Captive water storage for firefighting.	<i>Common pump house & UGWST for Mother & Child, Geriatrics and Service Block</i>		
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	2,00,000 Ltr	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 Ltr	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> Total area Location 	250 m ²	Provided	MR
		6 th Floor	Provided	MR

88

N-18

19.	Fire Control Room.			
	• Detector system panel.	Required	Provided	MR
	• Flow switch panel.	Required	Provided	MR
	• PA system panel.	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building floor plan	Required	Provided	MR
20.	Special Fire Protection System for Protection of special Risk, if any.	Required	Provided CO ₂ flooding system in electric panels	MR

The fire protection systems provided in the premises/building were checked, tested at random and found functional at the time of inspection. The shortcomings issued vide letter No. F.6/DFS/MS/SZ/2024/75 dated 23/02/2024 found complied.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter No. F6/DFS/MS/Hospital/2021/SZ/145 dated 24/02/2021, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal/approval & signature please.

Santosh Kumar
21/5/25
Signature of the Inspecting Officer
Name: Santosh Kumar
Designation: ADO (SJ)

DO (SD)

[Signature]
21/5/25

CO (MS)

[Signature]
23/5/2025

Director

[Signature]
24/5/25

AD(S)

Sir, F.T. Ltr is put up for your sig. pl

[Signature]
24/5/25
an

[Signature]
26/5/25