

4303

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001


No.F6/DFS/MS/Audi/NDZ/2025/ 439

Dated: 20/ 08 /2025

FIRE SAFETY CERTIFICATE

Certified that the M/s M.P.C.U. Shah Auditorium located at 02, Raj Niwas Marg, Delhi - 110054, comprised of Basement (below the lobby part of auditorium), ground plus one upper floor was granted Fire Safety Certificate by this department vide letter No. F6/DFS/MS/Audi/NDZ/2022/355 dated 08.08.2022. Now, the premises was re-inspected by the officer concerned of this department on 25.07.2022 in presence of Mr. Ashish (Supervisor) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the building having Basement + ground floor + 01 upper floor is fit for occupancy class "Assembly Building" with effect from 20/08/2025 renewed for a period of three years, in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 subject to conditions printed below.

Issued on 20/08/2025 at New Delhi by


19/8/2025
(Virendra Singh)
Chief Fire Officer
Delhi Fire Service
o/c 8u 19/8

Copy to:-

1. The Commissioner, Municipal Corporation of Delhi, Dr. SPM Civic Centre, New Delhi - 110002.
2. The Licensee, M.P.C.U. Shah Auditorium at 02, Raj Niwas Marg, Delhi- 110054.

Conditions for the validity of Fire Safety Certificate

1. The owner/occupier shall apply for renewal of this fire safety certificate to the Director in form J' (Sub rule(1) of rule 37) along with a copy of this certificate, six months prior to its expiry.
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	M.P.C.U. Shah Auditorium located at 02, Raj Niwas Marg, Delhi- 110054		
2	Building is comprised of	Basement (below the lobby part of auditorium) + ground + 01 upper floor		
3	Type of occupancy	Assembly building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/Audi/NDZ/2022/355 dated 08.08.2022		
6	Fire safety direction letter no.	Nil		
7	Date of inspection	25.07.2025		
8	Name of the inspecting officers	ADO (SPM)		
9	Name of the designation of officer from the building side	Mr. Ashish (Supervisor)		
10	Year of construction	1976		
11	Applicant's letter no.	email dated 24.07.2025		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	Requirement/ Existing fire safety arrangements	Provided at Site	Remarks MR/ NMR
1	Access To Building:			
	Road width	06 mtr.	06 mtr.	MR
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
	A	Number of staircases		
	a	Upper floor	01 no.	01 no. MR
	b	Basement	01 no.	01 no. MR
	B	Width of staircases		
	a	Upper floor	1.5 mtr.	1.5 mtr. MR
	b	Basement	1.5 mtr.	1.5 mtr. MR
	C	Protection of exits		
	a	Fire check door	NA	NA NA
	b	Pressurization	NA	NA NA
	D	No. of continuous staircases to terrace	01 no.	01no. MR
	E	Width of corridor	NA	NA NA
	F	Door size	1.5 mtr.	1.5 mtr. MR
3	Compartmentation:			
	A	Fire check door	NA	NA NA
	B	Sealing of electrical shafts	NA	NA NA
	C	Fire rating of shaft door	NA	NA NA
	D	Water curtain	NA	NA NA
	E	Fire dampers	NA	NA NA
4	Smoke Management System:			
	A	Upper floors	12 ACPH	Provided MR
	B	Basements	NA	NA NA

5.	Fire Extinguisher:				
	A	Total numbers	06 nos.	20 nos.	MR
	B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
	C	ISI marking	ISI marked	Provided	MR
6	First-Aid-Hose Reels:				
	A	Total numbers of each floor	03 nos.	03 nos.(02 nos. at ground floor & 01 no. at 1 st floor)	MR
	B	Length of hose reel hose	30 mtr.	30 mtr.	MR
	C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection And Alarming System:				
	A	Type of detectors	NA	NA	NA
	B	Location of main panel	NA	NA	NA
	C	Location of repeater panel	NA	NA	NA
	D	Alternate source of power	NA	NA	NA
	E	Hooters	NA	NA	NA
8	MOEFA:		NA	NA	NA
9	Public Address System:		Required	Provided	MR
10	Automatic Sprinkler System:				
	A	Basement	NA	NA	NA
	B	Upper floor	NA	NA	NA
	C	Sprinkler system on stage	Required	Provided	MR
11	Internal Hydrants:				
	A	size of riser/down-comer	NA	NA	NA
	B	Number of hydrants per floor	NA	NA	NA
	C	Hose box	NA	NA	NA
12	Yard Hydrants:				
	A	Total number of hydrants	01 no.	01 no.	MR
	B	Hose box	01 no.	01 no.	MR
13	Pumping Arrangements:				
	A	Ground level			
	a)	Discharge of main pump	NA	NA	NA
	b)	Head of main pump	NA	NA	NA
	c)	Number of main pumps	NA	NA	NA
	d)	Jockey pump out put	NA	NA	NA
	e)	Jockey pump head	NA	NA	NA
	f)	Standby pump out put	NA	NA	NA
	g)	Standby pump head	NA	NA	NA
	h)	Auto starting /manual stopping	NA	NA	NA
	i)	Pump house access	NA	NA	NA
	B	Terrace level			
	a)	Discharge of pump	900 LPM	900 LPM	MR
	b)	Head of the pump	45 mtrs.	45 mtrs.	MR
	c)	Power supply	Required	Provided	MR
	d)	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage For Fire Fighting:			
A	Underground tank capacity	50,000 ltrs.	50,000 ltrs.	MR
B	Draw-off connection	Required	Provided	MR
C	Fire service inlet	Required	Provided	MR
D	Access to tank	Required	Provided	MR
E	Overhead tank capacity	16,000 ltrs.	16,000 ltrs.	MR
15	Exit Signage:	Required	Provided	MR
16	Provision of Lifts:			
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Firemen's grounding switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17	Standby Power Supply:	Required	Provided	MR
18	Refuge Area:			
A	Total area	NA	NA	NA
B	Location	NA	NA	NA
19	Fire Control Room :			
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	Pa system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
20	Special Fire Protection Systems For Protection of Special Risks, If Any:		NA	NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the Rules, the FSC issued vide letter no. **F6/DFS/MS/Audi/NDZ/2022/355 dated 08.08.2022** is recommended to be renewed under Rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
 Name Sumit Kumar
 Designation ADO (SPM)

DO (CD)

5/8

Sy. C.F.O. (M22)

C.F.O.

12/8/2025

12/8/2025

Principal Director

ADO (SPM)

CFO to Secy.

CFO

12/8/25

PFO

P.T.O.