



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No: F.6/DFS/MS/2026/WZ/ 530

Dated: 29/05/2026

To,

The Assistant Engineer (Bldg.),
MCD, Narela Zone, Zonal Building,
Narela, Delhi- 110040.

Sub:- Issuance of Fire Safety Certificate in respect of M.R. Bharti School of Nursing Run by Omwati Education Trust located at Kh. No. 53/6, Village Mundka, Delhi- 110041.

Sir,

This has reference to your letter no. AE/B/NRZ/2026/D-29 dated 11/05/2026 received through outdoor diary no. 1181 dated 13/05/2026 on the subject cited above. In this connection, it is to inform you that the inspection of above said educational building has been carried out by the officer concerned of this department on 21.05.2026 to see the compliance of the requisite fire safety measures. Mr. Himanshu Lakra was present at the time of inspection.

Your request for issuance of FSC is rejected as the following shortcomings were observed:-

1. Exit door at terrace floor shall be open outwards.
2. First Aid Hose reels found provided but not functional.
3. Terrace level pump of 450 lpm discharge capacity not found in auto mode.
4. Overhead tank of 5000 ltrs water storage capacity found provided against the requirement of 10000 ltrs.
5. Exit signage's and lift signage's found not provided.
6. Passage to the alternate exit is not permitted from the activity hall.

You are advised to rectify the above-mentioned shortcoming for taking further action as necessary for issuance of Fire Safety Certificate. Till such time the occupancy of the building is at the risk and responsibility of owner/ occupier.

Yours Faithfully

27/05/26
(S.K Dua)

Chief Fire Officer
Delhi Fire Service

Copy to :-

1. The Principal, M.R. Bharti School of Nursing run by Omwati Education Trust, located at Kh. No. 53/6, Village Mundka, New Delhi-110041.