



No. F6/DFS/MS/School/NDZ/2025/ 1095

Dated: 03/09/2025

FIRE SAFETY CERTIFICATE

Certified that the M.S.W. Public School located at B – 369, Gali No. 5, Babu Nagar, Karawal Nagar, Delhi – 110094, building comprised Ground plus three upper floors only School is running at ground plus two upper floors only, 3rd floor is guard room and store room as per affidavit dated 19/08/2025), owned/occupied by M.S.W Public School have complied with the Fire Prevention and Fire Safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 19/08/2025 in the presence of Mr. Mohd. Bashim (Manager) and observed that all the fire prevention and fire safety requirements provided in the premises found in good working condition. and that the school building is fit for occupancy “Educational Building” (class B) Ground plus two upper floors only with effect from 03/09 /2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 03/09/2025 at New Delhi by.


21/9/2025
VIRENDRA SINGH
CHIEF FIRE OFFICER
o/c DELHI FIRE SERVICE


Copy to: -

1. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi - 110054.
2. The Principal, M.S.W Public School, B – 369, Gali No. 5, Babu Nagar, Karawal Nagar, Delhi – 110094.

Conditions for the validity of Fire Safety Certificate

1. **This fire safety certificate is valid for ground plus two upper floors only.**
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipment's and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the firefighting equipment's shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc. may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.

N/05
INSPECTION REPORT

1.	Name & address of the building	M.S.W Public School located at B – 369, Gali No. 5, Babu Nagar, Karawal Nagar, Delhi – 110094.		
2.	Building is comprised of	Ground plus three upper floors (School is running at ground plus two upper floors only, 3rd floor is guard room and store room as per affidavit dated 19/08/2025)		
3.	Type of occupancy	Educational Building		
4.	Type of case	New Case		
5.	Details of previous FSC	Nil		
6.	Fire safety directives letter no.	NBC Part - IV		
7.	Date of inspection	19/08/2025		
8.	Name of the inspecting officers	Yashwant Singh Meena ADO, Laxmi Nagar		
9.	Name of the designation of officer from the building side	Mr. Mohd. Bashim (Manager)		
10.	Year of construction	2022		
11.	Applicant's letter no.	Outdoor Dairy No. 4472 dated 04.08.2025		
S. No	Minimum standard of fire prevention and fire safety U/R 33	NBC Part - IV Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building:			
	A	Road width	6.0 meters.	6.0 meters.
	B	Gate width	N/A	N/A
	C	Width of internal road	N/A	N/A
2.	Number, Width, Type and Arrangement of Exits:			
	A	Number of staircases		
	a	Upper floor	02 nos.	02 nos.
	b	Basement	N/A	N/A
	B	Width of staircases		
	a	Upper floor	1.50 meters.	1.50 meters.
	b	Basement	N/A	N/A
	C	Protection of exits		
	a	Fire check door	N/A	N/A
	b	Pressurization	N/A	N/A
	D	No. of continuous staircases to terrace	01 no.	01 no.
	E	Width of corridor	1.50 meters	1.71 meters.
	F	Door size	1.20 meter.	1.20 meter.
3.	Compartmentation:			
	A	Fire check door	NA	NA
	B	Sealing of electrical shafts	N/A	N/A
	C	Fire rating of shaft door	N/A	N/A
	D	Water curtain	N/A	N/A
	E	Fire dampers	N/A	N/A
4.	Smoke Management System:			
	A	Basement	N/A	N/A
	B	Upper floor	N/A	N/A

③ X

5. Fire Extinguisher:				
A	Total numbers	10 nos.	10 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI Marked	ISI Marked	MR
6 First-Aid-Hose Reel:				
A	Total numbers of each floor	01 no.	01 no.	MR
B	Length of hose reel hose	30 meters.	30 meters.	MR
C	Nozzle diameter	05 mm	05 mm	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8 MOEFA:		N/A	N/A	N/A
9 Public Address System:		N/A	N/A	N/A
10 Automatic Sprinkler System:				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:				
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
12 Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:				
1 Ground level				
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2 Terrace Level				
A	Discharge of pump each block	450 LPM	450 LPM	MR
B	Head of the pump	40 mtrs.	40 mtrs.	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting:			
A	Underground tank capacity	N/A	N/A	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	10,000 liters	Provided	MR
15	Exit Signage:	Required	Provided	MR
16	Provision of Lifts:			
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17	Standby Power Supply:	N/A	N/A	N/A
18	Refuge Area:			
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19	Fire Control Room:			
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			

Note: - Building comprised Ground plus three upper floors (School is running at ground plus two upper floors only, 3rd floor is guard room and store room as per affidavit dated 19/08/2025)

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections. The earlier shortcomings issued vide letter no. F6/DFS/MS/School/NDZ/2024/711 dated 16.10.2024 by this department have been rectified by the management.

Keeping in view of the substantial compliance of the minimum standards of fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
Name Yashwant Singh Meena
Designation ADO (L.N)

D.O/ East
By CFO (N.S.2)
CFO
Principal Director
Add (L.N)
P.T.O

CFO to Same.
28/08/25
29/08/25