



C-64

75  
Azadi Ka  
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/198

Dated: 07/04/2025

To

Ms. Anjali Kharbanda (Principal),  
N. K. Bagrodia Public School,  
Sector-4, Dwarka,  
New Delhi-110078

Sub: **Inspection report in r/o N. K. Bagrodia Public School located at Sector-4, Dwarka  
New Delhi-110078**

Sir,

Please refer to your application (Form 'J') received through outdoor diary No. 14663 dated 18/03/2025. In this connection, the premises was inspected by the officer concerned of this department on 18/03/2025 from fire & life safety point of view. Mr. Anil Goel and other staff was present. During the inspection, the shortcomings observed are as below: -

1. Terrace level fire pump was not on auto mode.
2. Electric panel found installed in the escape route.
3. Use of ground & basement floor for bank may be clarified.

In view of the above, renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in the absence of valid fire safety certificate/requisite fire safety measures, shall be at the risk and liability of school management.

Yours faithfully,

(ATUL GARG)  
DIRECTOR  
Ph. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054