



C-20

75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2025/SZ/ 189

Dated: 03/04/2025

To

The Principal,
N. K. Bagrodia Junior School,
Sector-4, Dwarka, New Delhi-110078

Sub: Inspection report in r/o N. K. Bagrodia Junior School located at Sector-4, Dwarka New Delhi-110078.

Sir,

This has a reference to your application (Form 'J') received through outdoor diary No. 11218 dated 09/01/2025. In this connection, it is to inform you that the premises was inspected by the officer concerned from this department on 18/03/2025 in the presence of Mr. Anil Kumar Goel (Accountant) from fire safety point of view. During course of inspection, the shortcomings observed are as below: -

1. Hose reel hose provided found non-functional.
2. Terrace level fire pump was not on auto mode.
3. Exit signage's found removed at some locations.

In view of the above, renewal of Fire Safety Certificate is rejected. You are advised to rectify the shortcomings under intimation to this department for further consideration in the matter. The occupancy of the premise/building in the absence of requisite fire safety arrangement shall be at the risk and responsibility of school management.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T. No. 011-23414000

9/4/25

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054