



212
in the name of the

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[See sub-rule (1) of rule 35]

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No.F6/DFS/MS/EH/2026/NDZ/ 61

Dated: 21/01/2026

FIRE SAFETY CERTIFICATE

Certified that the **M/s Nadoo (A Unit of Nadoo Restaurants Pvt. Ltd.)** located at E-5, Ground Floor, LSC Musjid Moth, Greater Kailash-II, New Delhi-110048 building comprising of Basement, Ground plus two upper floors but Eating House is running on ground floor only, owned/occupied by **M/s Nadoo (A Unit of Nadoo Restaurants Pvt. Ltd.)** have complied fire prevention and fire safety requirements in accordance with rule of the Delhi Fire Service Rules. 2010 and verified by the officers concerned of Fire Service on dated 08/01/2026 in the presence of Sh. Sahil Sambhi and that the building/premises is fit for occupancy class "**Assembly**" **Eating House (ground floor only)** with effect from 21/01/2026 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010 & also conditions printed below.

Issued on 21/01/2026 at New Delhi by.

(A. K. MALIK)
DY. CHIEF FIRE OFFICER
OLC 2 DELHI FIRE SERVICE

1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy a detailed above.
2. The Owner/Occupier, M/s Nadoo (A Unit of Nadoo Restaurants Pvt. Ltd.) located at E-5, Ground Floor, LSC Musjid Moth, Greater Kailash-II, New Delhi-110048

MCD ID No. 2025122716160

Conditions for the validity of Fire Safety Certificate

1. FSC is valid for ground floor only
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the firefighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. Construction of lift lobby or installation of Fire curtain in the lift shall be provided by the management within six months failing which Fire Safety Certificate should be treated null a& void.
7. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.

1. 4 Name & address of the building : M/s Nadoo (A Unit of Nadoo Restaurants Pvt. Ltd.)
E-5, Ground Floor, LSC Musjid Moth, Greater Kailash-II, New Delhi-110048

2. Building is comprised of : Basement, Ground plus two upper floors but restaurant is running ground floor only

3. Type of Occupancy : Assembly (Restaurant)

4. Type of Case : New

5. Details of Previous NOC letter : Nil

6. Fire Safety directive letter No : N/A

7. Date of Inspection : 10/01/2026

8. Name of the Inspecting officers : Deepak Kumar, ADO (TP/Shd.)

9. Name and designation of Officer from the building side : Sh. Sahil Sambhi

10. Year of Construction : 2015

11. Applicant's letter No : 2025122716160 dated 27/12/2025

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	NBC Part IV Requirements	Provided at Site	Remarks MR/NMR
01	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	06 m N/A N/A	06 mtr N/A N/A	MR N/A N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases <ul style="list-style-type: none"> Upper Floor Basement b. Width of Staircases <ul style="list-style-type: none"> Upper Floor Basement c. Protection of exits <ul style="list-style-type: none"> Fire check door Pressurization d. No. of continuous staircases to terrace e. Width of Corridor f. Door Size	N/A N/A N/A N/A N/A 01 no. 1.50 mtr. 1.50 mtr	01 no. 01 no. 1.25 mtr 1.25 mtr N/A N/A 01 no. 02 mtr. 02 mtr & 1.67 mtr	N/A N/A N/A N/A N/A MR N/A N/A N/A N/A N/A N/A
03	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire rating of shaft door Water curtain Fire Dampers 	Required N/A N/A N/A N/A	Provided in the kitchen N/A N/A N/A N/A	MR N/A N/A N/A N/A
04	Smoke Management System			
	<ul style="list-style-type: none"> Basement Upper floor 	N/A 12 ACPH	Provided Provided	N/A MR
05.	Fire Extinguishers.			
	<ul style="list-style-type: none"> Total numbers types ISI marking 	02 nos. ABC/CO ₂ Required	06 nos. ABC/CO ₂ Provided	MR MR MR

06	First-aid-Hose Reels.			
	Total numbers on each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA			
09	Public address System.			
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose Box	01 no.	01 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements			
	• Ground Level			
	➢ Discharge of main Pump	N/A	N/A	N/A
	➢ Head of Main Pump	N/A	N/A	N/A
	➢ Number of main pumps	N/A	N/A	N/A
	➢ Jockey pump out put	N/A	N/A	N/A
	➢ Jockey pump head	N/A	N/A	N/A
	➢ Standby pump out put	N/A	N/A	N/A
	➢ Standby pump Head	N/A	N/A	N/A
	➢ Auto Starting /Manual stopping	N/A	N/A	N/A
	➢ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➢ Discharge of pump	450 lpm	450 lpm	MR
	➢ Head of the Pump	40 m	40 m	MR
	➢ Power supply	Required	Provided	MR
	➢ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➢ Draw-off connection	N/A	N/A	N/A
	➢ Fire service inlet	N/A	N/A	N/A
	➢ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	20,000 ltrs	20,000 ltrs	MR
15	Exit Signage.			
16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

xy/5

17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule. **It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.**

Accordingly, DFA is put up for approval and signature please.

Last Date:- 28/01/2026

Deepak 30/01/2026.

Signature of the Inspecting Officer
Name :- Deepak Kumar
Designation :- A.D.O (TP/Shah.)

DO (SD)

12/1/26
Ravinder Singh

Jyotsna

Amritpal
A.K. MALIK

Principal Director

My. AP (CSZ)

Amritpal
A.K. MALIK

DO (SD)

ADM TD/SD

Dr. C. S. to Room.

(SD) 30/01/26

19/1/26