



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

C-21



No.F.6/DFS/MS/School/2025/NDZ/ 500

Dated: 09/06/2025

To,

The Principal,
Nagar Nigam Pratibha Vidyalaya
Kailash Nagar Gali No. 12,
Delhi-110031


Subject:-Regarding issuance of Fire Safety Certificate in r/o Nagar Nigam Pratibha Vidyalaya located at Kailash Nagar Gali no. 12, Delhi-110031.

Sir,

This is in reference to your letter no. nil dated 09/04/2025 on the subject cited above. In this connection, it is to inform you that officer concerned of this department has visited the school on dated 20/05/2025 in presence of In-charge of the school and observed that the shortcomings as communicated earlier vide letter No. F.6/DFS/MS/2021/NDZ/55 dated 09/02/2022 (copy enclosed) have not been complied yet.

In view of the above, Fire Safety Certificate cannot be considered at this stage. You are requested to rectify the shortcomings communicated vide above mentioned letter under intimation to this office for further action.

Yours faithfully


6/6/2025
(VIRENDRA SINGH)
CHIEF FIRE OFFICER

Encl. As above

Copy to:-

The Director of Education (MCD)
15th Floor, E-Block, Dr. S.P. Mukahrjee Civic Center, JLN Marg, New Delhi-110002

19
C-20
E-15

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No. F6/DFS/MS/School/2021/NDZ/ 55

Dated: 09/02/2022

To,

The Principal,
E. D. M. C. Primary School,
Kailash Nagar, Gali No. 12,
Delhi-110031

Subject:- Regarding issuance of Fire Safety Certificate.

Sir,

With reference to your letter no. E.E. (Elect.)-II/Shah(S)/2021-2022/D-570 dated 27/10/2021 on the subject cited above, it is informed that officer concerned of this department inspected the school from fire safety point of view in presence of Ms. Manisha Kumari, Principal & Sh. Kuldeep Kumar Singh, J.E (Electric), Shahdara South Zone on dated 29/11/2021. The school building comprises of ground plus three upper floors. During the course of inspection following observations was made:-

1. Two staircase of width 1.5 meter each is required to be provided in the building.
2. Complete set of building plans are not submitted.
3. Approach road width is less than 6 meter.

In view of the above, the school building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to rectify the above mentioned fire safety arrangements under intimation to this office for further necessary action.

Yours faithfully,


(K. D. Garg)
Director
58..

Copy to:-

The Director of Education, EDMC
Udyog Sadan, Plot No. 419, FIE,
Patparganj, Delhi -92