

C/S7

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI-110 001.

No.F.6/DFS/MS/Metro/2025/SZ/489

Dated: 16/09/2025

FIRE SAFETY CERTIFICATE

Certified that the Najafgarh Underground Station of Dwarka-Najafgarh Corridor Phase-III, New Delhi-110043, comprised of three levels (Undercroft, Platform, Concourse) & Ancillary Building was issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/Metro/2022/SZ/527 dated 24.11.2022. The building was re-inspected by the officer concerned of this department on dated 09.09.2025 in the presence of Sh. Bhirgu Fukan (AM/Fire) and found that the management have complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Assembly Building D-7" (Assembly Building) w.e.f. 16/09/2025 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on 16/09/2025 at New Delhi.


(Virendra Singh)
Chief Fire Officer

Copy to:-

Sh. Rajesh Agarwal, GM/E&M, Delhi Metro Rail Corporation Ltd., Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-110001

Conditions for validity of Fire Safety Certificate:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Najafgarh Underground Station of Dwarka-Najafgarh Corridor Phase-III, New Delhi-110043.
2. Building comprised of : Concourse level, Platform level, Undercroft level, ancillary bldg. & associated tunnels
3. Type of Occupancy : Assembly Building D-7
4. Type of Case : New
5. Details of Previous NOC : F6/DFS/MS/Metro/2022/SZ/527 dated 24.11.2022
6. Fire Safety directives letter No. : F.6/DFS/MS/BP/2018/298 dated 26.09.2018
7. Date of inspection : 09.09.2025
8. Name of Inspecting Officer : A.D.O. R.K. Yadav
9. Name and designation of officers
From the building side : Sh. Bhirgu Fukan (AM/Fire)
10. Year of Construction : 2019
11. Applicant's letter No. : DMRC/O & M/Fire/NOC/L-9/2025/08/06/03 dated 12.08.2025


| Sr. No. | Minimum Standards on fire prevention and fire safety U/R 33 | NFPA/UBBL-16 NBC-17 Requirement | Provided at site | Remarks MR/NMR |
|---------|---|---|---|-------------------------|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> Road width Gate width Width of internal road | 09 Mtrs. N/A N/A | Provided Directly accessible from road N/A | M/R N/A N/A |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | | | |
| | <ul style="list-style-type: none"> Upper floors Basement | N/A | N/A | N/A |
| | | 1. Under croft to platform-2 no.'s 2. Platform to concourse 6 no.'s+ 04 Escalator 3. Concourse to Ground 4 no.'s+03 escalator | 1. Provided 2. Provided 3. Provided | M/R MR MR |
| | b. Width of staircases | | | |
| | <ul style="list-style-type: none"> Upper floors Basements | 125 cms | Provided | M/R |
| | | 1. 1.0 m UL to PL (02 no.'s) 2. 5.6 m (02 no.'s)+4.6 m (01 no.)+1. 5m (01 no.), + 1.2m (01 no.) + 5.5 m (01 no.) PL to CL 3. 4.7m (01 no.), +5.6 m (01 no.), + 5.7 m (01no.), + 1.2 M (01 no.) CL to GL | 1. Provided 2. Provided 3. Provided | MR MR MR |
| | c. Protection of exits | | | |
| | <ul style="list-style-type: none"> Fire/smoke check door Pressurization | Required | Provided | MR |
| | | Required in enclosed staircase | Provided | MR |
| | d. No. of continuous staircases to terrace | | | |
| | | N/A | N/A | N/A |
| | e. Width of Corridor | 02 mtrs | Provided | MR |
| | f. Door Size | 01 mtrs | Provided | MR |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers | Required | Provided | MR |
| | | Required | Provided | MR |
| | | 01 Hr 30 Min. | Provided | MR |
| | | N/A | N/A | N/A |
| | | Required | Provided | MR |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> Basements Upper floor | Required | Provided | MR |
| | | N/A | N/A | N/A |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers Types IS marking | 60 No.'s ABC/CO ₂ type ISI marked | Provided Provided Provided | M/R M/R M/R |

| | | | | |
|-----|---|---|---|--|
| 6. | First-Aid Hose Reels | | Provided | M/R |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | 01 no. pump room & 01 no. chiller plant room, 10 no.'s at CL, 08 no.'s at PL 30 mtrs 6 mm | Provided | M/R |
| | | | Provided | M/R |
| 7. | Automatic fire detection and alarming system | | Provided | MR |
| | <ul style="list-style-type: none"> Type of detectors smoke/heat Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | Required Stn. Control room Required Required Required | Provided Provided Fireman S/case Provided All areas | MR MR MR MR MR |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | Required | Provided | MR |
| 10. | Automatic Sprinkler System/Spray nozzle system | | Provided | MR |
| | <ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling | Required in storage area & under carriage of platform track side spray nozzles N/A N/A | N/A N/A N/A | N/A N/A N/A |
| 11. | Internal Hydrants | | Provided | MR |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box | 150/100 mm 01 no. pump room & 01 no. chiller plant room, 10 no.'s at CL, 08 no.'s at PL 01 no. pump room & 01 no. chiller plant room, 10 no.'s at CL, 08 no.'s at PL | Provided Provided Provided | MR MR MR |
| 12. | Yard Hydrants | | Provided | MR |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | 01 no. in ancillary bldg. 01 no. in ancillary bldg. | Provided Provided | MR MR |
| 13. | Pumping Arrangements | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put (Electrical) Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump | 1620 LPM 88 mtrs & 75 mtrs Two 180 LPM (02 no.'s) 88 mtrs & 75 mtrs 1620 LPM (02 no.'s) 88 mtrs & 75 mtrs Required Required N/A N/A N/A N/A | 2839 LPM 88 mtrs & 75 mtrs Two 189 LPM (02 no.'s) 88 mtrs & 75 mtrs 2839 LPM (02 no.'s) 88 mtrs & 75 mtrs Provided Provided N/A N/A N/A N/A | MR MR MR MR MR MR MR MR MR MR N/A N/A N/A N/A |
| 14. | Captive Water Storage for fire fighting | | | |
| | <ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity | N/A Required Required Required 50,000 ltrs | N/A Provided Provided Provided 2,00,000 ltrs. | N/A M/R M/R M/R M/R |
| 15. | Exit Signage. | Required | Provided | M/R |
| 16. | Provision of Lifts. | | | |



| | | | | |
|-----|---|--|----------|-----|
| | <ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage | N/A | N/A | N/A |
| | | N/A | N/A | N/A |
| | | Required | Provided | M/R |
| | | Required | Provided | M/R |
| | | Required | Provided | M/R |
| 17. | Standby power supply | Required | Provided | M/R |
| 18. | Refuge Area. | | | |
| | ➤ Total Area | N/A | N/A | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19. | Fire Control Room | | | |
| | <ul style="list-style-type: none"> Detector System Panel Flow Switch Panel PA System Panel Battery backup Building Floor Plans | Required | Provided | M/R |
| | | Required | Provided | M/R |
| | | Required | Provided | M/R |
| | | Required | Provided | M/R |
| | | Required | Provided | M/R |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | Clean agent fire trace tube system for ASS room Panels | Provided | MR |

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/Metro/2022/SZ/527 dated 24.11.2022 is **recommended to be renewed** under rule 37, of the Delhi Fire Service Rules, 2010.


 Signature of Inspecting Officer
 Name: - R.K. Yadav
 Designation: - ADO (JKP)

DO (South West)


 10/9/25
 C.F.O.

 10/9/2025

Principal Director

C.F.O. to Issue

 12/09/25

C.F.O.

 15/9/2022

ADO (JKP)