



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

cl/40
7/5
आज्ञादीय
अमृत महोत्सव

No. F6/DFS/MS/School/NDZ/2025/ 115

Dated: 17/02/2025

To,

The Principal,
Nalanda Cambridge School
Kh. No. 1146/787, Gali No. 13,
Nalanda Chowk, Vishnu Garden,
Main Road Mandawali Fazalpur,
Delhi – 110092.

Subject: - Regarding grant of Fire Safety Certificate in r/o Nalanda Cambridge School located at Kh. No. 1146/787, Gali No. 13, Nalanda Chowk, Vishnu Garden, Main Road Mandawali Fazalpur, Delhi – 110092.

Sir,

This has a reference to your Outdoor Diary No. 11740 dated 24/01/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 08/02/2025 in the presence of Mrs. Sunita (In- Charge) and observed that building comprised of ground plus two upper floors.

Following shortcomings were observed during time of inspection:

1. First-Aid-Hose Reel at each floors provided but not functional.
2. Internal Hydrant provided at ground floor only that is also not functional.
3. Fire pump of 450 LPM provided but not functional.
4. Over head water storage tank of capacity 10,000 liters not provided.
5. Exit & floors Signage's not provided in strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

1. The Joint Director of Education, MCD, Udyog Sadan, Plot No.419, FIE, Patargang, Delhi - 110092.