

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/WZ/2025/ 46

Dated:- 30/01/2025

To,

Sh. Rajesh Aggarwal (GM/E&M),
Metro Bhawan, Fire Brigade Lane,
Barakhamba Road, New Delhi-110001.

Sub.:- Regarding renewal of Fire Safety Certificate in respect of Nangloi Railway Metro Station (Elevated) (Line-5), located at Nangloi, New Delhi-110041.

Sir,

This has reference to your letter no. DMRC/No.& R./FSC/Line-5/2024/12/35 dated 31/12/2024 on the subject cited above. In this connection it is to inform you that the above metro station building has been inspected by the officer concerned of this department on 23/01/2025 in the presence of Sh. Ravinder Kumar (Fire Insp.) & sh. Dinesh Kumar (Jr. Eng. E & M). However, the following shortcomings have been observed as under:-

1. Automatic fire detection system found non-functional.
2. Automation mode of fire pumps found non-functional.

In view of the above shortcoming, the application for renewal of Fire Safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,



(Atul Garg)
Director