



c/188



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

Dated: 31/01/2025

No.F.6/DFS/MS/EH/2025/SZ/ 49

To,  
The Joint Commissioner (Lic.)  
1<sup>st</sup> floor Police Station Defence Colony,  
New Delhi

**Subject: -Regarding renewal of Fire Safety Certificate in r/o M/s Narangs International Hotels Pvt. Ltd. A Unit of Ambassador's Sky Chef at IGI Airport Complex Near Centaur Hotel, Delhi-110037.**

Sir,

This is in reference to online portal ID.2025010200062 dated 08/01/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above mentioned Eating House from fire safety point of view in presence of Mr. D.S. Dogra (CSO) on dated 23/01/2025. The building comprised of basement & ground floor only. The following shortcomings were observed during the time of inspection.

1. Smoke Detector found removed in the basement.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)  
DIRECTOR

o/c DELHI FIRE SERVICE

Copy to:-

The D.S. Dogra  
M/s Narangs International Hotels Pvt. Ltd. A Unit of Ambassador's Sky Chef  
IGI Airport Complex Near Centaur Hotel, Delhi-110037.