

G/36

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

No F6/DFS/MS/EH/SZ/2025/ 314

Dated: 22/07/2025

To

The Commissioner,
Municipal Corporation of Delhi,
Dr. SPM Civic Centre, New Delhi - 110002.

Sub: Regarding renewal of Fire Safety Certificate in r/o M/s Nathu's Sweets located at Shop/Prop. No. 19, Ground Floor, Community Centre, New Friends Colony, New Delhi - 110025.


Sir,

This has reference to MCD online application ID No. 2025062310466 dated 23.06.2025 received on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 02.07.2025 in presence of Mr. Vipin Gupta (Owner) and it was observed that building is comprised of Basement + Ground + Mezzanine + 02 upper floors but restaurant is running at ground floor only. During inspection, following shortcomings were observed:

1. Fire extinguishers provided but some found non functional.
2. First aid hose reel provided but not functional.
3. MOEFA provided but not functional.
4. Automatic sprinkler system provided in basement but not maintained.
5. Terrace fire pump not on auto start mode.

In view of above shortcoming, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/ premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Virendra Singh)
Chief Fire Officer
Delhi Fire Service

Copy to:-

The Licensee,
M/s Nathu's Sweets at Shop/Prop. No. 19, Ground Floor, Community Centre, New Friends Colony,
New Delhi - 110025.

o/c
84
22/7