

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी का
अमृत महोत्सव

C/25

No. F6/DFS/MS/EH/WZ/2026/412

Dated:- 27/04/2026

FIRE SAFETY CERTIFICATE

Certified that the M/s. Nathu Sweets, located at 1963/2 Ground Floor, Kh. No. 379, Railway Road, Pana Udyan, Main Bazar Narela, Delhi-110040, in the building comprised of ground + 02 upper floors & Tin shed on terrace floor but restaurant is running at ground floor only, owned/occupied by M/s. Nathu Sweets, The said premise was re-inspected by the officer concerned of this department on 30/03/2026 in the presence of Sh. Rajiv Gupta (Owner) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group D "Assembly Building" (Restaurant) for ground floor only with effect from 27/04/2026 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 27/04/2026 at New Delhi by.

[Signature]
27/04/26
S.K. Dua
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Commissioner, Municipal Corporation of Delhi, Civic Centre, Minto Road, New Delhi-110002:- in r/o online application id. 2026031703029 dated 17/03/2026.
2. The Authorized Signatory, M/s. Nathu Sweets, located at 1963/2 Ground Floor, Kh. No. 379, Railway Road, Pana Udyan, Main Bazar Narela, Delhi-110040.

Conditions for the validity of fire safety certificate :-

1. This FSC is valid only for restaurant at ground floor for assembly occupancy only. In case of any violation, this FSC will be treated as null & void.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
6. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
7. All comments / directions of licensing Department shall always be permitted and followed.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
9. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/s. Nathu Sweets, located 1963/2, G.F., Kh. No. 379, Delhi- Railway Road, Pana Udyan, Main Bazar Narela, 110040
2. Type of Occupancy : Assembly Building (Restaurant)
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 06/04/2026
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (BW)
8. Name and designation of Officer from the building side : Sh. Rajceev Gupta (Owner)
9. Year of Construction : 2000 (as mentioned in online application)
10. Applicant's letter no. : 2026031703029 dated 17/03/2026

The building is comprised of ground + two upper floors + Tin Shed on terrace floor only but restaurant is running at ground floor only.

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC (Part-IV) Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.5 m x 2	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Ground floor	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	04 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI Marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01 no.	Provided	MR
		30 m	Provided	MR
	• Length of hose reel hose	5 mm	Provided	MR
	• Nozzle diameter			
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided	MR
	• Number of hydrants per floor	01 no.	Provided	MR
	• Hose Box	01 no.	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for firefighting:			

[Handwritten signature]

N/A.


	- Underground tank capacity - Draw off connection - Fire service inlet - Access to tank - Overhead Tank capacity	NA NA NA Required 20,000 ltrs.	NA NA NA Provided 2,0000 ltrs.	NA NA NA MR MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	- Pressurization of Lift Shaft - Pressurization of lift lobby - Communication in lift Car - Fireman's Grounding Switch - Lift Signage	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	- Total area - Location	NA NA	NA NA	NA NA
19.	Fire control room			
	- Detector system panel - Flow Switch Panel - PA System Panel - Battery backup - Building Floor Plans	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards of fire prevention & fire safety measures as required under the rules and it is **recommended** to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010.


Accordingly, DFA is prepared & put up for approval please.



Aman Kumar Lathar
ADO (BW)



10/04/2026


Dy CFO (COZ) Pl. spk about Fire check door
of kitchen.


15/04/26



16/04/2026

ADO/Bhuzang
Sir, there is no at Ground Floor and
an undertaking has been obtained from the owner
and placed opposite on file.


20/04/26

