

CPD

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001

No.F6/DFS/MS/NDZ/2025/ 193

Dated:-02/05/2025

To

The Manager
M /S Nathus Sweets and Restaurant (A Unit of SIAA SIAA Hospitality LLP)
Bearing no. RZ-14/5, GF, Kh. No. 180BLIQ7OBLIQ2,
Revenue Estate, Delhi Colony, Laxmi Garden,
Najafgarh, Delhi – 110043.

Sub: Regarding issuance of FSC in r/o M/S Nathus Sweets and Restaurant (A Unit of SIAA SIAA Hospitality LLP) located at bearing no. RZ-14/5, GF, Kh. No. 180BLIQ7OBLIQ2, Revenue Estate, Delhi Colony, Laxmi Garden, Najafgarh, Delhi – 110043.

Sir,

This has reference to online id no.2025040405554 dated 07.04.2025, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on **28/04/2025** in the presence of Manager and following shortcomings were observed:-

1. Alternate staircase provided of .75 m in basement against the requirements of 1.5 meter.
2. Smoke Management system not provided.
3. Fire check door is not provided in basement for compartmentation as the staircase is directly open to kitchen area.
4. Alternate exit is provided of 1.0 meter against the requirements of 1.5 meter.
5. First aid hose reel found non functional and hydrant systems with hose box is not provided.
6. 02 no. terrace pump of 450 LPM is required against the providing of 01 nos and same should be in auto mode provision also.
7. Overhead tank of 25000 liter is required against providing of 10,000 liter.

In view of above, the case is rejected. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,

(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.