

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI **HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No.F6/DFS/MS/WZ/2025/College 144

Dated: - 04/12 2025

To,

Sh. Dhirender Khatri, Administrative Officer, National Institute of Homeopathy, Ministry of Ayush, Govt. of India, Sector-A8, Chaudhary Ramdev Chowk, Narela, Delhi-110040.

Subject: Regarding renewal of Fire Safety Certificate in respect of National Institute of Homeopathy, Delhi, located at Sector-A8, Chaudhary Ramdev Chowk, Narela, Delhi-110040.

Sir,

This has reference to your letter no. P-16023(12)/2025-US C1/1/238 dated 17/10/2025 on the subject cited above. In this connection, it is to inform you that above said building was inspected by the officers concerned of this department on 15/11/2025 in the presence of Sh. Dheeraj Saimil (J.E., Civil) & Ms. Shivi Singh (J.E., Electrical). During inspection, it has been observed that the said building is comprised of 02 Blocks, Hospital Block (B+G+5), Academic Block (B+G+4). However, the following shortcomings have been observed as under:-

- 1. Smoke Management system found non-functional.
- 2. Automatic fire detector system found non-functional.
- 3. MOEFA found non-functional.
- 4. Public Address System found non-functional.
- 5. Pressurization of Staircases/Lift well/Lift lobbies were provided but found nonfunctional.
- Fire pump were provided but not on auto mode.
- 7. Firefighting system/detection system are not integrated.
- 8. No trained fire staff was available during the time of inspection.

In view of the above shortcomings, the application for renewal of fire safety certificate cannot be considered at this stage & rejected. You are requested to submit point wise compliance & till such time occupancy of the building/premises in absence of requisite fire safety arrangements shall be at your own risk and responsibility.

Yours faithfully,

Dy. Chief Fire Officer (WZ)