




No. F6/DFS/MS/School/NDZ/2025/ 937

Dated: 01/08/2025

FIRE SAFETY CERTIFICATE

Certified that the **National Victor Public School** located at **I. P Extension, Patparganj, Delhi - 110092**, building comprised of Ground plus three upper floors only, owned/occupied by **National Victor Public School** was issued FSC vide letter No. F6/DFS/MS/School/NDZ/2022/790 dated 27/07/2022. The school building was re-inspected by the officers concerned of this department on 19/07/2025 in presence of Dr. Veena Mishra (Principal) and found that school building have deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. 262 - 362 dated 17/01/2005 issued by Director of Education and the building premises is fit for occupancy of class **"Educational Building" (Group "B")** with effect from 01/08/2025 for a period of **three years** in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 01/08/2025 at New Delhi by.


29/7/2025
VIRENDRA SINGH
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
ok (10)

Copy to: -

1. The Dy. Director of Education, D - Block, Anand Vihar, Delhi - 110092.
2. The Principal, National Victor Public School, I.P Extension, Patparganj, Delhi - 110092.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner / occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	National Victor Public School located at I.P Extension, Patparganj, Delhi - 110092.		
2	Building is comprised of	Ground plus three upper floors ("U" shape building)		
3	Type of occupancy	Educational Building (Group- B)		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/NDZ/2022/790 dated 27/07/2022		
6	Fire safety directives letter no.	DOE Circular No. 262 - 362 dated 17/01/2005		
7	Date of inspection	19/07/2025		
8	Name of the inspecting officers	Yashwant Singh Meena, A.D.O / Laxmi Nagar & Ashok Kumar Jaiswal, Divisional Officer / East		
9	Name of the designation of officer from the building side	Dr. Veena Mishra (Principal)		
10	Year of construction	2000		
11	Applicant's letter no.	Outdoor Dairy No. 3673 dated 11/07/2025		
S. No	Minimum standard of fire prevention and fire safety U/R 33	Requirement NBC/UBBL	Provided at site	Remarks MR/NMR
1.	Access to Building:			
	A Road width	6.0 mtrs.	10 mtrs. ✓	MR
	B Gate width	N/A	N/A	N/A
	C Width of internal road	N/A	N/A	N/A
2.	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	03 nos.	03 nos. ✓	MR
	Basement	N/A	N/A	N/A
	B Width of staircases			
	a Upper floor	1.50 mtrs.	1.58 mtrs. each ✓	MR
	Basement	N/A	N/A	N/A
	C Protection of exits			
	a Fire check door	N/A	N/A	N/A
	b Pressurization	N/A	N/A	N/A
	D No. of continuous staircases to terrace	01 no	03 nos.	MR
	E Width of corridor	1.50 mtrs	2.70 mtrs ✓	MR
	F Door size	1.0 mtr.	1.20 mtr.	MR
3.	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	N/A	N/A	N/A
	C Fire rating of shaft door	N/A	N/A	N/A
	D Water curtain	N/A	N/A	N/A
	E Fire dampers	N/A	N/A	N/A
4.	Smoke Management System:			
	A Basement	N/A	N/A	N/A
	B Upper floor	N/A	N/A	N/A


③


5. Fire Extinguisher:				
A	Total numbers	18 nos.	20 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	Required	Provided	MR
6 First-Aid-Hose Reel:				
A	Total numbers of each floor	03 nos.	03 nos.	MR
B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
C	Nozzle diameter	05 mm	05 mm	MR
7 Automatic Fire Detection and Alarming System:				
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	MOEFA:	N/A	Provided	N/A
9	Public Address System:	N/A	Provided	N/A
10 Automatic Sprinkler System:				
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11 Internal Hydrants:				
A	Size of riser/down-comer	100 mm	100 mm	MR
B	Number of hydrants per floor	03 nos.	03 nos.	MR
C	Hose box	03 nos.	03 nos.	MR
12 Yard Hydrants:				
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13 Pumping Arrangements:				
1	Ground level			
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2	Terrace Level			
A	Discharge of pump each block	450 LPM	450 LPM X 03 nos.	MR
B	Head of the pump	40 mtrs.	40 mtrs.	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

14 Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	N/A	50,000 liters ✓	N/A
B	Draw-off connection	N/A	N/A	N/A
C	Fire service inlet	N/A	N/A	N/A
D	Access to tank	N/A	N/A	N/A
E	Overhead tank capacity	5,000 liters	30,000 liters ✓	MR
15 Exit Signage:		Required	Provided	MR
16 Provision of Lifts:				
A	Pressurization of lift shaft	N/A	N/A	N/A
B	Pressurization of lift lobby	N/A	N/A	N/A
C	Communication in lift car	N/A	N/A	N/A
D	Firemen's grounding switch	N/A	N/A	N/A
E	Lift signage	N/A	N/A	N/A
17 Standby Power Supply:		N/A	N/A	N/A
18 Refuge Area:				
A	Total area	N/A	N/A	N/A
B	Location	N/A	N/A	N/A
19 Fire Control Room:				
A	Detector system panel	N/A	N/A	N/A
B	Flow switch panel	N/A	N/A	N/A
C	PA system panel	N/A	N/A	N/A
D	Battery backup	N/A	N/A	N/A
E	Building floor plans	N/A	N/A	N/A
20 Special Fire Protection systems for protection of special Risks, if any:		N/A		

The fire protection system was randomly checked and tested and was found functional at the time of inspection.

Keeping In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules of FSC issued vide letter no. F6/DFS/MS/School/NDZ/2022/790 dated 27/07/2022, renewal under Rule 35 of the Delhi Fire Service rules 2010, is recommended.


Signature of the Inspecting Officer
Name: Yashwant Singh Meena
Designation: ADO /Laxmi Nagar


Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation: Divisional Office/ East

Dy CFO (NDZ)

KVP
21/07/25

C.F.O.

KVP
22/07/2025

Principal Director

Cfo to Genl.

KVP
22/07/25

Cfo

KVP
23/07/2025

DO (East)

KVP
25.7.2025

ADOL.N
A.G.D.