

cl22



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/School/NDZ/2025/ 215

Dated: 15/04/2025

To,

The Principal,  
Nav Jeevan Adarsh Public School,  
A-Block, Street No.16, Part-3,  
Circular Road, Sonia Vihar, Delhi-110094.

**Subject: - Regarding grant of Fire Safety Certificate in r/o Nav Jeevan Adarsh Public School,  
A-Block, Street No.16, Part-3, Circular Road, Sonia Vihar, Delhi-110094.**

Sir,

This has a reference to your Outdoor diary No. 14373 dated 12/03/2025, on the subject cited above. In this connection, it is to inform you that premises was inspected by the officer concerned of this department on 03/04/2025 in the presence of Mr. Amit Kumar Bansal (Principal) and observed that building comprised of ground plus three upper floors.

**Following shortcomings were observed during time of inspection:**

1. First-Aid-Hose Reel found removed.
2. Fire pump of 450 LPM found removed.
3. Over head water storage tank of capacity 10,000 liters found removed.
4. Exit & floors Signage's found removed at strategic location in the building.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

1. The Dy. Director of Education, B - Block, Yamuna Vihar, Delhi - 110053.