



No. F6/DFS/MS/School/NDZ/2025/ 100

Dated: 18/08/2025

FIRE SAFETY CERTIFICATE

Certified that the Nav Jeevan Adarsh Public School located at A - Block, Street No. 16, Part - 3, Circular Road, Sonia Vihar, Delhi - 110094, earlier building comprised of Ground plus two upper floors for which NOC/FSC was issued by this department vide letter no. F6/DFS/MS/School/2022/NDZ/296 dated 21/03/2022, owned/occupied by Nav Jeevan Adarsh Public School is now comprised of Ground plus three upper floors have complied with fire prevention and fire safety requirements in accordance with rule 33 of DFS Rules of this department on 23/07/2025 in presence of Mr. Amit Bansal (Principal) and that the building premises is fit for occupancy class (Group - B) "Educational Building" for Ground plus three upper floors only with effect from 18/08/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 18/08/2025 at New Delhi by.

(VIRENDRA SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to: -

1. The Dy. Director of Education, B - Block, Yahuma Vihar, Delhi - 110053.
2. The Principal, Nav Jeevan Adarsh Public School at A - Block, Street No. 16, Part - 3, Circular Road, Sonia Vihar, Delhi - 110094.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner / occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

~~N/A~~ - N/17 -
INSPECTION REPORT

1	Name & address of the building	Nav Jeevan Adarsh Public School located at A - Block, Street No. 16, Part - 3, Circular Road, Sonia Vihar, Delhi - 110094.		
2	Building is comprised of	(Ground + 03 upper floors)		
3	Type of occupancy	Educational Building		
4	Type of case	New (3 rd floor added on existing G+ 02)		
5	Details of previous FSC	F6/DFS/MS/School/2022/NDZ/296 dated 21/03/2022 (For G+2)		
6	Fire safety directives letter no.	NBC Part - IV		
7	Date of inspection	23/07/2025		
8	Name of the inspecting officers	Yashwant Singh Meena, ADO/Laxmi Nagar		
9	Name of the designation of officer from the building side	Mr. Amit Bansal (Principal)		
10	Year of construction	2010 & 2016		
11	Applicant's letter no.	Outdoor diary No. 3643 dated 11/07/2025		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Circular requirement	Provided at site	Remarks MR/NMR
1	Access to Building:			
A	Road width	6.0 mtrs.	6.0 mtrs.	MR
B	Gate width	N/A	N/A	N/A
C	Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits:			
A	Number of staircases			
a	Upper floor	02 no.	02 no.	MR
b	Basement	N/A	N/A	N/A
B	Width of staircases			
a	Upper floor	1.50 mtrs.	1.50 mtr. & 1.60 mtr.	MR
b	Basement	N/A	N/A	N/A
C	Protection of exits			
a	Fire check door	N/A	N/A	N/A
b	Pressurization	N/A	N/A	N/A
D	No. of continuous staircases to terrace	02 no	02 no	MR
E	Width of corridor	1.5 mtr.	1.5 mtr.	MR
F	Door size	1.0 mtr.	1.0 mtr.	MR
3	Compartmentation:			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	N/A	N/A	N/A
C	Fire rating of shaft door	N/A	N/A	N/A
D	Water curtain	N/A	N/A	N/A
E	Fire dampers	N/A	N/A	N/A
4	Smoke Management System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A


@ A

Extinguisher:				
A	Total numbers	12 nos.	30 nos.	MR
B	Types	CO ₂ & ABC	CO ₂ & ABC	MR
C	ISI marking	ISI Marked	ISI Marked	MR
6	First-Aid-Hose Reel:			
A	Total numbers of each floor	02 nos.	02 nos.	MR
B	Length of hose reel hose	30 m	30 m	MR
C	Nozzle diameter	05 mm	05 mm	MR
7	Automatic Fire Detection and Alarming System:			
A	Type of detectors	N/A	N/A	N/A
B	Location of main panel	N/A	N/A	N/A
C	Location of repeater panel	N/A	N/A	N/A
D	Alternate source of power	N/A	N/A	N/A
E	Hooters	N/A	N/A	N/A
8	MOEFA:	N/A	N/A	N/A
9	Public Address System:	N/A	N/A	N/A
10	Automatic Sprinkler System:			
A	Basement	N/A	N/A	N/A
B	Upper floor	N/A	N/A	N/A
C	Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants:			
A	Size of riser/down-comer	N/A	N/A	N/A
B	Number of hydrants per floor	N/A	N/A	N/A
C	Hose box	N/A	N/A	N/A
12	Yard Hydrants:			
A	Total number of hydrants	N/A	N/A	N/A
B	Hose box	N/A	N/A	N/A
13	Pumping Arrangements:			
1	Ground level			
A	Discharge of main pump	N/A	N/A	N/A
B	Head of main pump	N/A	N/A	N/A
C	Number of main pumps	N/A	N/A	N/A
D	Jockey pump out put	N/A	N/A	N/A
E	Jockey pump head	N/A	N/A	N/A
F	Standby pump out put	N/A	N/A	N/A
G	Standby pump head	N/A	N/A	N/A
H	Auto starting /manual stopping	N/A	N/A	N/A
I	Pump house access	N/A	N/A	N/A
2	Terrace Level			
A	Discharge of pump	450 LPM	450 LPM	MR
B	Head of the pump	40 m	40 m	MR
C	Power supply	Required	Provided	MR
D	Auto starting of pump	Required	Provided	MR

14	Captive Water Storage for Fire Fighting:			
	A	Underground tank capacity	N/A	N/A
	B	Draw-off connection	N/A	N/A
	C	Fire service inlet	N/A	N/A
	D	Access to tank	N/A	N/A
	E	Overhead tank capacity	10,000 liters Required	10,000 liters Provided
15	Exit Signage:			
16	Provision of Lifts:			
	A	Pressurization of lift shaft	N/A	N/A
	B	Pressurization of lift lobby	N/A	N/A
	C	Communication in lift car	N/A	N/A
	D	Firemen's grounding switch	N/A	N/A
	E	Lift signage	N/A	N/A
17	Standby Power Supply:			
18	Refuge Area:			
	A	Total area	N/A	N/A
	B	Location	N/A	N/A
19	Fire Control Room:			
	A	Detector system panel	N/A	N/A
	B	Flow switch panel	N/A	N/A
	C	PA system panel	N/A	N/A
	D	Battery backup	N/A	N/A
	E	Building floor plans	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:			


The fire protection system was randomly checked and tested and was found functional at the time of inspection. The shortcomings issued by this department vide letter no. F6/DFS/MS/School/NDZ/2025/215 dated 15/04/2025 has been rectified.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to grant Fire Safety Certificate under Rules 37 of Delhi Fire Service Rules 2010.


 Signature of the Inspecting Officer
 Name Yashwant Singh Meena
 Designation ADO/Laxmi Nagar

~~D.O/EAST~~ DFA please.

Dy CFO (NDZ) 
 31.7.2025
 LRP
 01/08/25

C.F.O. 
 9/8/2025
 Principal Director

CFO to 

ADO (LN)




 12/8/2025

P.T.O