

c/37

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6./DFS/MS/BP/2025/ 248

Dated: 04/06/2025

To,

The MS, Nursing Home Cell
Directorate General of Health Services,
Govt. of NCT of Delhi, S-1, 3rd Floor,
School Block, Shakarpur, Delhi – 110092.

Sub: - Regarding issuance of fire safety directives in R/o Navjeevan Maternity and Child Care Hospital, A-14, Pushpanjali Enclave, Opp. Jaipur Golden Red Light Outer Ring Road, Pitampura, Delhi – 34.

Sir,

Please refer your letter No. F.24/New/North-West/DGHS/NHC/2025/212 dated 05/05/2025 on the subject cited above. In this connection it is to inform you that the matter has been examined and observed that it is to inform you that the building plans were scrutinized from fire safety point of view and observed that there is a proposal of building at A-14, Pushpanjali Enclave, Opp. Jaipur Golden Red Light Outer Ring Road, Pitampura, Delhi – 34. Following shortcomings are observed:

1. Fire safety arrangements such as Underground Fire water tank, Terrace tank, and Fire pumps etc. are not proposed as per NBC-Part-4 & UBBL-2016.
2. Lift lobby is not provided as per clause 7.11(0) of UBBL-16.
3. Staircase is not protected with fire check door as per NBC-Part-4 & UBBL-2016.

Therefore, case is rejected.

Yours faithfully,


(Virendra Singh)
Chief Fire Officer
Ph. 011-23412225

w