

C/42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6./DFS/MS/BP/2025/ 15442
To,

Dated: 04/09/2025

The Authorized Signatory
Navjeevan Maternity and Child Care Hospital,
A-14, Pushpanjali Enclave,
Opp. Jaipur Golden Red Light Outer Ring Road,
Pitampura, Delhi – 34.

Sub: - Regarding issuance of fire safety directives in R/o Navjeevan Maternity and Child Care Hospital, A-14, Pushpanjali Enclave, Opp. Jaipur Golden Red Light Outer Ring Road, Pitampura, Delhi – 34.

Sir,

Please refer your letter No. NMCC/2025/57/FIRE/I dated 12/08/2025 vide diary No. 4794 dated 12/08/2025 on the subject cited above. In this connection it is to inform you that the matter has been examined and observed that it is to inform you that the building plans were scrutinized from fire safety point of view and observed that there is a proposal of building at A-14, Pushpanjali Enclave, Opp. Jaipur Golden Red Light Outer Ring Road, Pitampura, Delhi – 34. Following shortcomings are observed:

1. Exit doorways are not opening as per clause 7.12.5 of UBBL- 2016.
2. The Underground water Pumps 01 electric pump and 01 diesel pump of 1620 LPM capacity and 01 electric Jockey pump of 180 LPM are not proposed as per NBC Part IV- 2016.

Accordingly, the case is hereby rejected.

Yours faithfully,


3/9/2025
(Virendra Singh)
Chief Fire Officer
Ph. 011-23414333


Copy to: -

The MS, Nursing Home Cell
Directorate General of Health Services,
Govt. of NCT of Delhi, S-1, 3rd Floor,
School Block, Shakarpur, Delhi – 110092.