

c 26

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/1286

Dated: 04/11/2025

**FIRE SAFETY CERTIFICATE**

Certified that the building of Navyug Primary School located at Jor Bagh, New Delhi – 110003, comprised of ground plus one upper floor only, was issued Fire Safety Certificate vide this department letter No. F.6/DFS/MS/School/SZ/2022/1061 dated 22/09/2022. The premise was re-inspected by the officer concerned of this department on 17/10/2025 in the presence of Sh. Brahma Prakash Upadhyay (Principal) and found that said premises have deemed complied with the fire prevention and fire safety requirements in accordance Director of Education Circular No. 3298 to 3398 dated 01/03/2011 D.O.E Circular 262-232 dated 17/01/2005 and that the said premises/building is fit for occupancy class “**Educational Group B**” with effect from 04/11/2025 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 04/11/2025 at New Delhi by



(A.K. Malik)  
Dy. Chief Fire Officer, SZ  
Delhi Fire Service  
ok

Copy to: -

1. Sh. Brahma Prakash Upadhyay (Principal), Navyug Primary School located at Jor Bagh, New Delhi - 110003
2. The Director of Education, MCD, Dr. SPM Civic Centre, JLN Marg, New Delhi-110002

**Condition for the validity of fire safety certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working conditions at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used as per the provisions of BBL.
4. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
5. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, prior to its expiry.
6. The owner/occupier shall submit a declaration every year in form “K” provided in the first schedule of Delhi Fire Service Rules, 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. Few trees are found in 9-meter-wide fire tender movement path. The trees shall be trimmed at regular interval for unhindered fire tender operation.

N/15

INSPECTION REPORT				
1.	Name & address of the building	Navyug Primary School located at Jor Bagh, New Delhi - 110003		
2.	Type of Occupancy	Educational (Group B)		
3.	Building Comprised of	Ground + 01 floor.		
4.	Type of Case	Renewal		
5.	Details of previous NOC No.	F6/DFS/MS/School/SZ/2022/1029 Dt. 19/09/2022		
6.	Fire Safety directives Letter No.	D.O.E Circular 262-232 dated 17/01/2005		
7.	Date of inspection	17/10/2025		
8.	Name of the Inspecting Officer	ADO (SJ)		
9.	Name and designation of Officer from the building side	Sh. Brahma Prakash Upadhyay (Principal)		
10.	Year of Construction	1988		
11.	Applicant's letter No.	No. A.E./D-1234/FIRE dated 01/09/2025 Outdoor diary No. 5986 dated 15/09/2025		
S. No.	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	N/A	N/A	N/A
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 Nos.	02 Nos.	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	01 Staircase of 1.5m or if main staircase width is < 1.5m an additional staircase of 0.75 mtr width is required	1.50m & 1.20m	MR
	• Basements		N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	01 No.	01 No.	MR
	e. Width of Corridor	1.50 mtr	1.50 mtr	MR
	f. Door Size	1 mtr	1 mtr. (Class Room)	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Managements System			
	• Basements	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	04 Nos.	04 Nos.	MR
	• Types	ABC & CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	01 No.	01 No.	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR

7.	Automatic fire detection and alarming system			
	• Type of detector	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• <b>Ground Level</b>			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• <b>Terrace level</b>			
	➤ Discharge of pump	220 LPM	380 LPM	MR
		40 mtr	40 mtr	MR
	➤ Head of the pump	Required	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump			
14.	Captive water storage for firefighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	2,500 ltrs	3,000 ltrs	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
✓	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Battery backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A

N/17

20.	Special Fire Protection Systems for Protection of Special Risks, if any;	N/A	N/A	N/A
-----	--	-----	-----	-----

The fire protection systems provided in the building were checked, tested at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, the fire safety certificate issued vide letter F6/DFS/MS/School/SZ/2022/1029 Dt. 19/09/2022, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for perusal/approval & signature please.

Signature of the Inspecting Officer  
Name: Kaushal Kishore  
Designation: ADO (SJ)

DO (SJ)

*[Signature]*  
21/10/22

*[Signature]*  
22/10/22

*[Signature]*  
22/10/22  
**A.K. MALIK**  
Principal

Dy. Cfo to Secy.  
*[Signature]*  
22/10/22

Dy. Cfo (SZ)  
*[Signature]*

*[Signature]*  
24/10/22  
**A.K. MALIK**

DO/SB  
*[Signature]*

*[Signature]*  
28/10/22

DO/SB  
*[Signature]*  
27/10/22