

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**


No.F6/DFS/MS/2025/ School/ NDZ/ 1137

Dated: 16/09/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Navyug School (Secondary School) located at Pandara Park, Pandara Road, New Delhi comprises of Ground + 02 Upper floor only owned/occupied by Navyug School was earlier granted FSC( for ground and one upper floor ) by this department vide letter No. F6/DFS/MS/2022/School/NDZ/221 dated 23/02/2022. Now, the premises was re-inspected by the officer concerned of this department on 01-09-2025 in the presence of Mrs. Nidhi Mag (Vice Principal) and found that school building comprising of ground and two upper floor, has deemed complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and the building premises is fit for occupancy of class Group B "Educational Building" Sub-Div. B-I Ground and two upper floor with effect from ~~16/09/2025~~ 16/09/2025 for a period of three years subject to compliance of the conditions mentioned below:

Issued on .....16/09/2025..... at New Delhi by.

  
15/9/2025  
(Virendra Singh)  
Chief Fire Officer  
q/c

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. The Principal, Navyug School (Secondary School), Pandara Park, Pandara Road, New Delhi.
3. Sh. N. K. Gaur, Fire Officer, NDMC, Palika Kendra, New Delhi.
4. Director of Education, Govt. of NCT, Delhi.

**Condition for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

# INSPECTION REPORT

1. Name & address of the building:- Navyug School (Secondary School) at Pandara Park, Pandra Road New Delhi.
2. Type of occupancy:- Educational Group B-I, Gr.+02 Upper Floor
3. Type of case:- Renewal
4. Details of previous NOC:- No. F6/DFS/MS/2022/School/NDZ/221 dated 23/02/2022.
5. Fire safety directives No.- N/A
6. Date of inspection:- 01/09/25
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer  
From the building side:- Mrs. Nidhi Mag (Vice Principal)
9. Year of construction:- 1961
10. Applicant's letter No:- letter no. A.E/D-FIRE/1121 dated 07.08.2025

Old Case (Renewal)

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Exiting	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Approachable	06 mtr.	MR
	2) Gate width	Approachable	05 mtr.	MR
	3) Width of internal road	NA	05 mtr.	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	02	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	1.50 mtr of 01 staircase or 02 of any width	1.10 & 1.20 mtr.	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	01	MR
	E. Width of corridor	N/A	1.5 mtr.	MR
	F. Door size	1 mtr.	1.30 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	04 Nos.	12 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	N/A	N/A	N/A
6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	01	N/A



	2) Length of hose reel hose	N/A	30 mtr.	N/A
	3) Nozzle diameter	N/A	05 mm	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	Provided	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	450 LPM	N/A
	b) Head of pump	N/A	40 mtr.	N/A
	c) Power supply	N/A	Provided	N/A
	d) Auto starting of pump	N/A	Provided	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	5000 ltr.	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	2500 ltr.	N/A
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift	N/A	N/A	N/A

N/22

	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: ABC & CO2			MR

The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules if approved, we may renew the Fire Safety Certificate issued vide letter No. F6/DFS/MS/2022/School/NDZ/221 dated 23/02/2022. under Rule 35 of the Delhi Fire Service rules 2010, Accordingly, FSC is **recommended for approval** & DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

Name :- Ravinder Singh  
Designation :- ADO(CC)

Dn/22  
21/9/25

Sy. C.F.O. (NDZ)

KMP  
05/09/25

C.F.O.

KMP  
8/9/2025

Principal Director

CFO to J.S.M.

05/09/25

CFO

18/9

ADO (CC)

ADO