



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F6/DFS/MS/School/ECN/2026/117

Dated: -28/07/2026

FIRE SAFETY CERTIFICATE

Certified that the Navyug Sr. Sec. School located at Vinay Marg, Chanakyapuri, New Delhi comprises of Ground + 02 Upper Floors was earlier granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2023/SZ/465 dt. 10.07.2023. Now, the premises was inspected by the officer concerned of this department on 13/07/2026 in the presence of Sh. Satveer Singh, Leading Fireman (NDMC) and found that the said school premises has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class Group B "Educational Building" with effect from 28/07/2026 for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on 28/07/2026 at New Delhi by.


28/07/26

(Dr. S. K. Tomar)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Principal, Navyug Sr. Sec. School, Vinay Marg, Chanakyapuri, New Delhi.
2. The Directorate of Education, Govt. of NCT of Delhi, Room No. 12, Old Secretariat, Civil Lines, Delhi - 110054.
3. The Fire Officer, NDMC, Palika Kendra, Netaji Nagar, New Delhi - 110001.

Condition for the validity of Fire Safety Certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained firefighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

- 14/16 -
INSPECTION REPORT

1.	Name & address of the building	Navyug Sr. Sec. School, Vinay Marg, Chanakyapuri, New Delhi.		
2.	Type of occupancy	Educational Group - B		
3.	Building is Comprised of	Ground + 02 Upper Floors		
4.	Type of case	Renewal		
5.	Details of previous FSC No.	F.6/DFS/MS/School/2023/SZ/465 dt. 10.07.2023		
6.	Fire safety directives No.-	DOE Circular 262 to 362 dated 17.01.2005		
7.	Date of inspection: -	13/07/2026		
8.	Name of the inspecting officer: -	Sh. Bhupender Prakash, ADO(ND)		
9.	Name & designation of officer From the building side: -	Sh. Satveer Singh, Leading Fireman (NDMC)		
10.	Year of construction: -	1980		
11.	Applicant's letter No: -	DFS Online Portal ID: - 52026061003591 dated 22.06.2026		
S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement as per Circular of Director of Education - 2011	Provided at site	Remarks MR/NMR
1.	Access to Building			
	• Road width	Accessible	9.00 mtr.	MR*
	• Gate width	N/A	4.00 mtr.	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper floors	02 nos.	02 nos. & 01 no. to 1 st Floor only	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircase			
	• Upper floors	1.50 & 0.75 mtr.	1.50, 1.60 & 1.13 mtr. (up to 1 st floor)	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	01 no.	01 no.	MR (Old Case)
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1.00 mtr.	1.00 mtr.	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	• Basements	N/A	N/A	N/A
	• Upper floors	Required	Provided Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	12 nos.	12 nos.	MR
	• Types	ABC/CO ₂	ABC/CO ₂	MR
	• ISI marking	ISI marked	Provided	MR
6.	First-Aid Hose Reel			
	• Total number of each floor	01 no.	01 no.	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	5mm	5mm	MR
7.	Automatic Fire Detection & Alarming System.			
	• Type of detectors	N/A	N/A	N/A

BP

	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System	Provided		N/A
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	100 mm	MR
	• Number of hydrants per floor	01 no.	01 no.	MR
	• Hose box per floor	01 no.	01 no.	MR
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	Ground level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Stand by pump output	N/A	N/A	N/A
	• Stand by pump head	N/A	N/A	N/A
	• Auto starting/Manual stopping	N/A	N/A	N/A
	Terrace level			
	• Discharge of pump	450 LPM	450 LPM	MR
	• Head of pump	40 mtr	40 mtr	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	5,000 Ltrs	5,000 Ltrs	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Fireman's switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A

	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:	N/A	N/A	N/A

*PNF - Provided but Non-Functional, *MR - Meeting Requirement, *NMR - Not Meeting Requirement

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, if approved, we may renew the FSC issued vide letter No. F.6/DFS/MS/School/2023/SZ/465 dated 10.07.2023, under Rule 35(6) of the Delhi Fire Service Rules 2010.

Accordingly, DFA is prepared and put up for perusal and signature please.

Bhupender Prakash
21/7/2026
Bhupender Prakash
ADO (ND)

DO (NDD/ODD)

Sandeep
21/7/2026

CFO (ECN)

CFIOMR
22/7/26

L.F. to issue.

Prakash
21/7/26

Principal Director

CFO (ECN)

CFIOMR
24/7/26

Ado/ND

As approved F.T. letter is put up for signature please.

CFO (ECN)

CFIOMR
28/7/26

Bhupender Prakash
27/7/2026

MS