



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001



No. F.6/DFS/MS/EH/2026/ED/ 732

Dated: 29/07/2026

To

The Commissioner,
Municipal Corporation of Delhi,
9th Floor, Dr. SPM Civic Centre,
JLN Marg, New Delhi-110002,


Sub: **Regarding issuance of Fire Safety Certificate in r/o M/s Nazeer Foods located at Shop. No. 215, Gali No. 03, Monga Nagar, Karawal Nagar, Delhi-110094.**

Sir,

Please refer to online MCD portal application No. **2026070809629** dated 08/07/2026, on the subject cited above. In this connection, it is to inform you that the said premise was visited by the officer concerned of this department on 15/07/2026 in the presence of Sh. Satyam Singh (Manager) to verify the compliance of shortcomings communicated by this department vide letter No. F.6/DFS/MS/EH/NDZ/2026/267 dated 30/03/2026. During course of inspection, it was observed that the shortcomings are not yet complied.

In view of above, issuance of fire safety certificate cannot be considered at this stage & rejected. The occupancy of the premises in the absence of requisite fire & life safety provision shall be at the risk and liability of the owner/occupier/management.

Yours faithfully,


(Dr. S.K. Tomar)
Chief Fire Officer
Delhi Fire Service


Copy to: -

1. Mr. Danish, M/s Nazeer Foods located at Shop. No. 215, Gali No. 03, Monga Nagar, Karawal Nagar, Delhi-110094



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001

No. F.6/DFS/MS/EH/NDZ/2026/267

Dated 30/03/2026

2-52

To,

Mr. Danish
M/s Nazeer Foods A unit of Sudha Rao Danish and Co.
Shop No 215, Gali No. 03, Monga Nagar, Karawal Nagar,
Delhi-110094.

Subject: - Regarding renewal of Fire Safety Certificate in r/o M/s Nazeer Foods A unit of Sudha Rao Danish and Co. located at Shop No 215, Gali No. 03, Monga Nagar, Karawal Nagar, Delhi-110094.

Sir,

This has reference to MCD online application ID No. 2026022502030 dated 25/02/2026 on the subject cited above. In this connection, it is to inform you that the premises was visited by the officer concerned of this department on dated 16/03/2026 in presence of Mr. Danish, Owner. The building is comprised of ground plus two upper floors but restaurant is running on ground floor only. The following shortcomings were observed during the time of inspection.

1. Second door passing through the kitchen
2. Fire check door not provided in the kitchen.
3. Smoke management system not provided in the restaurant.
4. First aid hose reel provided but not functional.
5. Down comer is provided but not functional.
6. Terrace pump 450 lpm head 40 meter provided but not functional.
7. Overhead tank capacity 5,000 liters provided against the requirement of 20,000 liters.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


27/3/26

(Dr. S. K TOMAR)

DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi: to ensure the occupancy a detailed above

MCD ID No. 2026022502030