

c/3

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI- 110001

No. F.6/DFS/MS/EH/2025/SZ/ 185

Dated: 10/05/2025

FIRE SAFETY CERTIFICATE

Certified that the M/s Nazeer Food (Nazeer Hospitality Foods Limited) at G-09, Ground Floor, V3S Mall, Plot No. 10, Laxmi Nagar, New Delhi- 110092, building comprised of basement, ground plus three upper floors, **Restaurant running on ground floor only, owned/occupied by Nazeer Hospitality Foods Limited**, was issued FSC by this department vide Letter No. F.6/DFS/MS/EH/NDZ//2022/109 dated 28.04.2022. The Restaurant building was re-inspected by the officer concerned of this department on dated 02.05.2025 in the presence of Mr. Imran Ahmad, and found that the restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant building/premises (**Ground floor only**) is fit for occupancy class **Group "D" Assembly Building** w.e.f. 10/05/2025 and valid up-to 31.03.2028, accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 10/05/2025 at New Delhi.


 (Atul Garg)

Director

Delhi Fire Service

Online application Id 2022030403040 dated 15.04.2025

Copy to: - The Executive Engineer (Building), MCD, Civic Centre, Minto Road, New Delhi.

: -for information regarding use of basement.

Conditions for validity of Fire Safety Certificate: -

1. **This NOC is valid only for Ground floor.**
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
4. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
5. The trained staff should be available round the clock.
6. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
7. Basement strictly shall be used as per BBL.
8. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
9. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
10. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

- Name & address of the building: M/s Nazeer Food (Nazeer Hospitality foods limited) at G-09, ground floor, V3S Mall, Plot No. 10, Laxmi Nagar, New Delhi.
- Building is comprised of : Basement, ground plus three upper floors
- Type of Occupancy : Group D (Assembly) Restaurant running at ground floor only
- Type of Case : Renewal
- Details of Previous NOC : F.6/DFS/MS/EH/NDZ//2022/109 dated 28.04.2022
- Fire Safety directives letter No : N/A
- Date of inspection : 02.05.2025
- Name of Inspecting Officers : A.D.O. R.K. Yadav (JKP)
- Name and designation of officers : From the building side
- Year of Construction : Mr. Imran Ahmad
- Applicant's letter No. : 2006
- : MHA Portal ID 2022030403040 dated 15.04.2025

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | Requirements As per Old FSC | Provided at site | Remarks MR/NMR |
|--------|---|--|--|---------------------------------|
| 1. | Access to building | | | |
| | <ul style="list-style-type: none"> Road width Gate width Width of internal road | 12 m 4.5 m 06 m | 36 & 13.8 m 06 m 06 m | M/R M/R M/R |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases <ul style="list-style-type: none"> Upper Floors Basements b. Width of staircases <ul style="list-style-type: none"> Upper Floor Basements c. Protection of exits <ul style="list-style-type: none"> Fire check door Pressurization d. No. of continuous staircases to terrace | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A |
| | e. Width of Corridor f. Door Size | N/A 1.5 m | N/A 2.0 & 1.5 m | N/A MR |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers | Required Required 02 hours N/A N/A | Provided Sealed Provided N/A N/A | MR MR MR N/A N/A |
| 4. | Smoke Management System | | | |
| | <ul style="list-style-type: none"> Basements Upper floors | Required Required | Provided Provided | MR MR |
| 5. | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> Total numbers in restaurant Types ISI marking | 8 no.'s ABC/CO ₂ ISI marked | Provided ABC- 04 & Co2- 04 Provided | M/R M/R M/R |
| 6. | First-Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> Total numbers at each floor Length of hose reel hose Nozzle diameter | 2 Nos. 30 mtrs 5 mm | Provided Provided Provided | M/R M/R M/R |

| | | | | |
|-----|---|---|---|--|
| 7. | Automatic fire detection and alarming system in restaurant | | | |
| | <ul style="list-style-type: none"> Type of detectors Smoke/Heat Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location | Smoke/Heat Control Room Security Room Battery & DG Set Staircase | Provided Basement Provided Provided Provided | MR MR MR MR MR |
| 8. | MOEFA | | | |
| 9. | Public Address System | | | |
| 10. | Automatic Sprinkler System | | | |
| | <ul style="list-style-type: none"> Basement Upper floors/Restaurant Sprinkler above false ceiling | N/A N/A N/A | N/A N/A N/A | N/A N/A N/A |
| 11. | Internal Hydrants | | | |
| | (Common with V3S Mall) | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants Hose Box | 150 MM 02 no's 02 no's | 150 MM 02 no's 02 no's | M/R M/R M/R |
| 12. | Yard Hydrants | | | |
| | (Common with V3S Mall) | | | |
| | <ul style="list-style-type: none"> Total number of hydrants Hose Box | 05 05 | 05 05 | MR MR |
| 13. | Pumping Arrangements | | | |
| | (Common with V3S Mall) | | | |
| | <ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access | 2850 LPM 70 m 01 180 LPM 70 m 2850 LPM 70 m Required Required | 2850 LPM 70 m 01 180 LPM 70 m 2850 LPM 70 m Provided Provided | MR MR MR MR MR MR MR MR MR |
| | <ul style="list-style-type: none"> Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump | N/A N/A N/A N/A | N/A N/A N/A N/A | N/A N/A N/A N/A |
| 14. | Captive Water Storage for fire-fighting | | | |
| | (Common with V3S Mall) | | | |
| | <ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity | 1,00,000 ltrs Required Required Required 20,000 ltrs | 1,20,000 ltrs Provided Provided Provided 40,000 ltrs | MR MR MR MR M/R |
| 15. | Exit Signage. | | | |
| 16. | Provision of Lifts | | | |
| | <ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A | N/A N/A N/A N/A N/A |

N/7

| Standby power supply | | Required | Provided | M/R |
|----------------------|---|----------|----------|-----|
| 18. | Refuge Area. | | | |
| | ➤ Total Area | | | N/A |
| | ➤ Location | N/A | N/A | N/A |
| 19. | Fire Control Room | | | |
| | • Detector System Panel | N/A | N/A | N/A |
| | • Flow Switch Panel | N/A | N/A | N/A |
| | • PA System Panel | N/A | N/A | N/A |
| | • Battery backup | N/A | N/A | N/A |
| | • Building Floor Plans | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risks, if any: | | | |
| | | N/A | N/A | N/A |

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/EH/NDZ//2022/109 dated 28.04.2022, renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

[Signature]
5/5/2025
Signature of the Inspecting Officer
Name- R.K. Yadav
Designation- ADO (JKP)

~~DO (ED)~~

[Signature]
7/5/2025

By CFO (NDZ)

[Signature]
08/05/25

C.F.O.

[Signature]
10/5/2025
Director
[Signature]
10/5/25

[Signature]

[Signature]
13/5/25

[Signature]