

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F.6/DFS/MS/School/WZ/2025/ 1154

Dated: 18/09/2025

**FIRE SAFETY CERTIFICATE**

Certified that the N.C. Jindal Public School, located at Road No.73, West Punjabi Bagh, New Delhi-110026, comprised of two blocks 1<sup>st</sup> block is (sr. sec. block) ground + 02 upper floors & 2<sup>nd</sup> block is (primary section) ground + 02 floors both are inter connected & one auditorium at ground floor. Owned/ occupied by N.C. Jindal Public School has already issued FSC by this department vide letter No. F6/DFS/MS/WZ/School/2022/879 dated 11/08/2022. The premises was re-inspected by officer concerned of this department on 25/8/2025 in the presence of Sh. R.K. Sharma (Maintenance) and observed that the premises have deemed complied with Director of Education Circular dated 01/03/2011/NBC (Part-IV) and that the building/premises is fit for occupancy class "Educational" Group-B, with effect from 18/09/2025 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010 conditions mentioned below.

Issued on 18/09/2025 at New Delhi by

  
 17/9/2025  
 Virendra Singh  
 Chief Fire Officer

Copy to: -

1. The Principal, N.C. Jindal Public School, located at Road No.73, Punjabi Bagh New Delhi-110026.
2. The Director, Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).



# INSPECTION REPORT

32

1.	Name & address of the building	N.C. Jindal Public School Located at Road No. 73, Punjabi Bagh (West), New Delhi-110026.
2.	Type of Occupancy	Educational (Ground & 02 Upper Floors)
3.	Type of Case	Renewal
4.	Details of previous NOC	F6/DFS/MS/WZ/School/2022/879 dated 11/08/2022
5.	Fire Safety directives letter No	D.O.E. Circular No. 3298-3398 dated 01/03/2011
6.	Date of inspection	25/08/2025
7.	Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8.	Name and designation of officers from the building side	Sh. R.K. Sharma (Maintenance)
9.	Year of Construction	1985 (As per previous Inspection Report dtd. 30/07/2022)
10.	Applicant's letter No.	Email dated 07/08/2025

The said school is running in two blocks 1<sup>st</sup> block is (sr. sec. block) ground + 02 upper floors & 2<sup>nd</sup> block is (primary section) ground + 02 floors & both are inter connected & one auditorium at ground floor, was issued FSC vide letter no. F6/DFS/MS/WZ/School/2022/879 dated 11/08/2022.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks
1	Access to building			MR/NMR
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	6 mts 5 mts N/A	Provided Provided N/A	MR MR N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	02 NA	02 Provided NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> <li>Basements</li> </ul>	1.5m or not less than 0.75m NA	1 x 1.42m, 1 X 1.22m & 2X 1.37m NA	MR (Old case) NA
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	NA NA	NA NA	NA NA
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	1.5 m	1.55m Provided	MR
	f. Door Size	1 m (class rooms), 1.5X2 (Audi.)	1m (class rooms) 3X2m (Audi.) Provided	MR (Old case)
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire Rating of shaft door</li> <li>Water Curtain</li> <li>Fire Dampers</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4	Smoke Management System.			
	<ul style="list-style-type: none"> <li>Basements</li> <li>Upper floors</li> </ul>	NA NA	NA NA	NA NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	32 nos. CO <sub>2</sub> , ABC type ISI marked	Provided Provided Provided	MR MR MR




6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30mtr	Provided	MR
	• Nozzle diameter	05mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	NA	Smoke detectors (Audi.)	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	Provided (Audi.)	NA
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>			
		NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	Required (on stage of Audi.)		MR
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	100mm Provided	NA
	• Number of hydrants per floor	NA	Provided	NA
	• Hose Box	NA	Provided	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level	NA	NA	NA
	➤ Discharge of pump	450 LPM& 180LPM		MR
	➤ Head of the pump	40 mtr	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15,000 ltrs	Provided	MR
15	<b>Exit Signage.</b>			
		Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA

17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/WZ/School/2022/879 dated 1/08/2022, **renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.**

  
Signature of the Inspecting Officer  
Sarabjeet Singh ADO (MN)

  
Dy. CFO (WZ)

1/ADo/MN  
08/05


0/806-WD  
13/08/25



Received  
on 11.9.2025  
in this office  
after one month.

  
Principal Director

  
11/9/2025


CFO to Jsem.

  
15/08/25

  
Dy. CFO (WZ)  
  
ADO (MN)

  
15/9/2025

Sir, R.T is put up for your kind personal & signature please

  
C.F.O.  
17/9/2025

  
17/9/2025

me