

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001**

Dated: 26/05/2025

No.F6/DFS/MS/School/NDZ/2025/ 456

To

The Principal,  
NDMC Pratibha Vidhalay,  
Bhojla Pahari, Chadni Chowk, Delhi - 110006.

**Sub: - Regarding issuance of "Fire Safety Certificate" from fire safety point of view in r/o NDMC Pratibha Vidhalay, Bhojla Pahari, Chadni Chowk, Delhi - 110006.**

Sir,

This has reference to your letter outdoor diary No. 428 dated 09.04.2025 on the subject cited above. In this connection, this is to inform you that the school building was inspected by officer concerned from this department on 19.05.2025 in the presence of Mr. Deepak (Attendant) and found that the school building is comprised of ground plus one upper floor but school is running at ground floor only. During the inspection, following shortcomings were observed:-

1. The school building is not accessible to fire engine.
2. Fire extinguishers provided but not functional.
3. Exit signages are not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management.

Yours faithfully,

  
(Atul Garg)

Director o/c

Delhi Fire Service

Tel: 011-23414000

10 6/21/5  
21/5

**Copy to:-**

The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, Delhi.