



C/131



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

No.F.6/DFS/MS/GH/2025/SZ/ 72

Dated: 11/02/2025

To,  
The Joint Commissioner (Lic.)  
1<sup>st</sup> floor Police Station Defence Colony,  
New Delhi

**Subject: -Regarding renewal of Fire Safety Certificate in r/o M/s Neel Gagan Guest House located at WZ-80A, Mohan Nagar, Pankha Raod, New Delhi-110046.**

Sir,

This has reference to MHA Portal ID No. 202431102830 dated 15/01/2025 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of the above mentioned guest house from fire safety point of view in presence of Mr. Anil Kumar on dated 06/02/2025. The building comprised of basement & ground plus three upper floors but guest house is running ground to second floor only. The following shortcomings were observed during the time of inspection.

1. First-aid-Hose Reels are provided but not functional at the time of inspection.
2. Sprinklers are provided in the basement but not functional at the time of inspection
3. Terrace pump is not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire Safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

Mr. Anil Kumar.

Neel Gagan Guest House at WZ-80A, Mohan Nagar, Pankha Raod, New Delhi-110046