



C-139

75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/GH/2025/SZ/107

Dated: 03 / 03 / 2025

To

The Joint Commissioner of Police (Lic.),
1st Floor, P.S. Defense Colony
New Delhi-110049

Sub: Inspection report in r/o M/s Neelam Palace Dx. Guest House located at Property No. 7977, Arakashan Road, Pahar Ganj, New Delhi-110055

Sir,

This has a reference to online application No. 2025021702006 dated 17/02/2025. In this connection, it is to inform you that the said premise was inspected by the officer concerned of this department on dated 22/02/2025 in the presence of Sh. Javed (Manager) of the guest house, from fire safety point of view. During course of inspection, the shortcomings observed are as below.

1. First aid hose reel provided but non-functional.
2. Terrace fire pump was not on auto mode.
3. Overhead water storage tank found empty.

In view of the above, the application for renewal of fire safety certificate is rejected. The occupancy of the premises in the absence of requisite fire safety certificate/arrangements shall be at the risk and liability of the owner/occupier. The local/licensing authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

T.No. 011-23414000

Copy to: -

1. Sh. Neelam Malhotra M/s Neelam Palace Dx. Guest House located at Property No. 7977, Arakashan Road, Pahar Ganj, New Delhi-110055