

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI **HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2025/School/ 375

Dated: 13 /05/2025

To

Mrs. Geeta Tyagi (Manager) Neo Delhi Public School, Khasra No- 1384, Main Road, Swaroop Vihar, Near Shani Mandir, Delhi-36.

Sub: - Regarding issuance of fire safety certificate in r/o Neo Delhi Public School at Khasra No-1384, Main Road, Swaroop Vihar, Near Shani Mandir, Delhi-110036. Sir.

Please refer to your letter No- NDPS/04/2025 dated 28/04/2025 on the subject cited above. In this connection this is to inform you that the above mention site was visited by the officer concerned of this department on 01/05/2025 in the presence of Sh. Seeom Tyagi was also present at site to check the existing fire safety & means of escape measures. During inspection it has been observed that the education building is comprised of Ground & First floors. The observations/ shortcomings made are as under:-

- 1. Only one staircase is provided width 02m against the requirement of one more staircase width of 1.50 and both staircases continues from ground to terrace level.
- 2. All classroom doors width is 01m against the requirement of 1.20m.
- 3. Terrace level fire pump not in auto mode.
- 4. Terrace level fire fighting water tank capacity of 1,000ltr is provided against the requirement of 10,000ltr.
- 5. Exit signage and floor signage not provided at strategic locations in the school premises.
- 6. Standby power supply is not provided.
- 7. As built plan of the school building shall also be submitted.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of new school building is at your own risk & responsibility.

Yours faithf

Copy to:-

1. The Deputy Director of Education, Zone-VII, District North Lucknow Road, Timar Delhi - 110054