



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F.6/DFS/MS/School/2025/SZ/ 43

Dated: 17 / 01 / 2025

To

The Principal,  
Neo Great Mission Public School,  
Sector-5, Dwarka, New Delhi-110075

Sub: **Renewal of Fire Safety Certificate in r/o Neo Great Mission Public School located at Sector-5, Dwarka, New Delhi-110075**

Sir,

This has a reference to your letter No. NGMPS/Fire/DFS/2024/280 dated 27/12/2024, on the subject mentioned above. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on dated 08/01/2025 in the presence of Sh. Umashankar Prashad (Admin) from fire safety point of view. During course of inspection, the following shortcomings are observed: -

1. Corridor found encroached with almirah.
2. Hose-reel hose found non-functional.
3. Terrace pump found non-functional.
4. Water tank found empty.
5. Exit signage's found removed.

In view of the above, application for renewal of Fire Safety Certificate is rejected. You are requested to rectify the above shortcomings under intimation to this department for further consideration in the matter. The occupancy of the premise/building in the absence of requisite fire safety arrangement shall be at the risk and responsibility of school management.

Yours faithfully,

(ATUL GARG)  
DIRECTOR

T. No. 011-23414000

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054