



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**



No. F6/DFS/MS/2025/School/ 944

Dated: 01/08/2025

**FIRE SAFETY CERTIFICATE**

Certified that the Neo Shanti Niketan Public School located at A-Block, Indraprasth Colony, Amrit Vihar, Burari, Delhi-110084, comprised of ground & 02 upper floors but school is running at ground & first floor only owned/occupied by Neo Shanti Niketan Public School have complied with the fire prevention and safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 09/07/2025 in presence of Sh. Manoj Kumar (Manager) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have complied with requirements of circular issued by Director of Education vide letter no 262-362 dated 17.01.2005 and the building/ premise is fit for occupancy class "Group B Educational (School) for ground & first floor only" with effect from ..01/08/2025... for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ...01/08/2025... at New Delhi by

29/07/2025  
 Virendra Singh

Chief Fire Officer  
 Delhi Fire Service

Copy to: -

1. The Deputy Director of Education, GNCT of Delhi, Zone-VII, District North Lucknow Road, Timarpur, Delhi - 110054.
2. The Manager, Neo Shanti Niketan Public School located at A-Block, Indraprasth Colony, Amrit Vihar, Burari, Delhi-110084.

**Conditions for the validity of Fire Safety Certificate:**

1. The school management having given an affidavit dated 10/07/2025 for not to use 2<sup>nd</sup> floor in future. In case of any violation, the Fire Safety Certificate will be treated as null & void.
2. All the means of escape shall be kept free from any type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipment and method of smooth and speedy safe evacuation of occupants in case of emergency
4. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seem during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities. This Fire Safety Certificate is valid only for permanent building structure as per plan.
6. This fire safety certificate may not be treated in any case of regularizations of unauthorized construction/unauthorized use of land or activities, if any.
7. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on the official website of Delhi Fire Service i.e. [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

## INSPECTION REPORT

1. Name & address of the building : Neo Shanti Niketan Public School at A-block, Indraprasth Amrit Vihar, Burari, Delhi-110084.
2. Type of Occupancy : Educational
3. Composition of building : Ground & 02 upper floors, But (School is ruining on ground & first floor only) and 2<sup>nd</sup> floor not in use as per affidavit dated 10/07/2025
4. Type of Case : New (Previous NOC expired on dated 07/11/2009)
5. Details of previous NOC : F6/MS/DFS/2006/3294 Dated: 08/11/2006 (Gr. & first floor only)
6. Fire Safety directives letter No : Nil
7. Date of inspection : 09/07/2025
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Mr. Manoj Kumar (Manager)
10. Year of Construction : 2004
11. Applicant's letter No. : Letter No- Nil dated: 30/06/2025

	Minimum Standards on fire prevention and fire safety U/R 33	D.O.E Circular dated 17.01.2005 Requirements	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Directly Accessible	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	02 nos. of 1.10m	MR (being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	Provided	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	01	01m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR




5	<b>Fire Extinguishers</b>			
	• Total numbers	05nos	06nos	MR
	• Types	ABC/Co2	ABC-06	MR
	• ISI marking	Yes	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30m	30m	MR
	• Nozzle diameter	5mm	5mm	MR
7	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	225 LPM	Provided	MR
	➤ Head of the pump	40m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR

14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	2500 LTR	Provided	MR
15	<b>Exit Signage.</b>	NA	NA	NA
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	N/A	N/A	N/A
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular 17.01.2005, it is recommended to renewal of fire safety certificate issued vide this department letter of even no. F6/M5/DF5/2006/3294 Dated: 08/11/2006.

  
 Signature of the Inspecting Officer  
 Name :- C.L. Meena  
 Designation:- ADO/RN

D.B. Mukharjee (DO/NW)

DCFO/... 22.9.11/17  
Dated... 15/12/2011

By 15/12/2011  
15/2  
PTO