

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001



No. F6/DFS/MS/WZ/Hospital/2025/ 2 0 2

To.

Mr. Sanjay Saroha (Director),

Neonest Hospital,

Building at A-1/3, Prashant Vihar,

Rohini, Delhi-110085.

Sub: Renewal of FSC in r/o Neonest Hospital Building at A-1/3, Prashant Vihar, Rohini, Delhi-110085.

Sir.

Kindly refer to online e-mail dated 03.04.2025, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on 22.04.2025, in presence of Mr. Sanjay Saroha (Director), to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

- 1. Smoke management system in basement found removed.
- 2. Temporary structure/porta cabin found provided on terrace.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under: http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/ http://www.delhi.gov.in/wps/wcm/connect/doit fire/FIRE/Home/Forms

Yours faithfully

Ph; 011-23414000