



## GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2025/SZ/ | 0

Dated: 02/01/2025

To

Dr. Alka Sachdev, Polyclinic for New Delhi Centre for Sight (Pvt) Ltd, Plot No. 9, Sector-9, Dwarka, New Delhi-110076

Sub: Regarding renewal of Fire Safety Certificate in r/o Polyclinic for New Delhi Centre for Sight (Pvt) Ltd, Plot No. 9, Sector-9, Dwarka, New Delhi-110076

Sir,

This has a reference to your application (Form J), on the subject cited above. In this connection, it is to inform you that the premise was visited by the officer concerned of this department on 26/12/2024 to verify the compliance of shortcomings communicated by this department vide letter No. F6/DFS/MS/SZ/2024/394 dated 10/07/2024 in the presence of Dr. Lakshya Sharma. During the inspection, the existing and additional shortcomings observed are as below.

1. Pressurization system in staircase, lift lobby still non-functional.

2. Lift lobby found removed in basement.

3. Smoke management system in basement non-functional/on auto mode and extension of exhaust duct below the false ceiling in some areas not yet done.

4. Extension of sprinklers below the false ceiling not yet done.

5. Office/Call Center found running in basement is not approved by this department. Hence, approved/regularized plan from concerned building authority be provided.

In view of above, renewal of fire safety certificate cannot be considered at this stage. You are advised to rectify the above-mentioned shortcoming under intimation to this department for further consideration in this matter.

Yours faithfully,

123414000 Γ. Νο. 2011-23414000

Copy to: -

1. The Medical Superintendent Nursing Home, Directorate General of Health Services, 3<sup>rd</sup> Floor, DGD Building, S-1, School Block, Shakarpur, New Delhi–110092

2. The Dy. Director (L&I), DDA, Vikas Sadan, INA, New Delhi–110023